


Prüfbericht-Nr.: <i>Test report no.:</i>	CN2283DK 003	Auftrags-Nr.: <i>Order no.:</i>	244469877	Seite 1 von 23 Page 1 of 23
Kunden-Referenz-Nr.: <i>Client reference no.:</i>	2480431	Auftragsdatum: <i>Order date:</i>	2022-12-16	
Auftraggeber: <i>Client:</i>	Apex Solar Energy Technology GmbH Reisholzer Werftstr. 76 Düsseldorf 40589 Germany			
Prüfgegenstand: <i>Test item:</i>	Grid-connected PV Inverter			
Bezeichnung / Typ-Nr.: <i>Identification / Type no.:</i>	APEX-P3-xx(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K), APEX-P3-xx-G(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K)			
Auftrags-Inhalt: <i>Order content:</i>	A3 Certificate			
Prüfgrundlage: <i>Test specification:</i>	VDE-AR-N 4105/11.18 <i>Erzeugungsanlagen am Niederspannungsnetz – Technische Mindestanforderungen für Anschluss und Parallelbetrieb von Erzeugungsanlagen am Niederspannungsnetz</i> <i>Generators connected to the low-voltage distribution network – Technical requirements for the connection to and parallel operation with low-voltage distribution networks</i>			
Wareneingangsdatum: <i>Date of sample receipt:</i>	2023-01-12			
Prüfmuster-Nr.: <i>Test sample no.:</i>	A003402982-001			
Prüfzeitraum: <i>Testing period:</i>	2023-01-12 - 2023-01-13			
Ort der Prüfung: <i>Place of testing:</i>	TÜV Rheinland (Shanghai) Co., Ltd.			
Prüflaboratorium: <i>Testing laboratory:</i>	TÜV Rheinland (Shanghai) Co., Ltd.			
Prüfergebnis*: <i>Test result*:</i>	Pass			
geprüft von: <i>tested by:</i> Jiayu Hu	genehmigt von: <i>authorized by:</i> Jingge Pan			
Datum: <i>Date:</i> 2023-01-13	Ausstellungsdatum: <i>Issue date:</i> 2023-01-13			
Stellung / Position:	Project Engineer	Stellung / Position:	Reviewer	
Sonstiges / <i>Other:</i>	- Test procedure complied with E DIN VDE V 0124-100/06.20, see report CN2283DK 003 attachment 1 for detail. - The mentioned models listed on above are identical to the original models in the previous section report report CN2283DK 001 except for model name, trademark and license holder etc. See following pages for details.			
Zustand des Prüfgegenstandes bei Anlieferung: <i>Condition of the test item at delivery:</i>	Prüfmuster vollständig und unbeschädigt <i>Test item complete and undamaged</i>			
* Legende: P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet * Legend: P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested				
Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens. This test report only relates to the above mentioned test sample as. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.				

v05

Liste der verwendeten Prüfmittel
List of used test equipment

Equip.	Description	Model	Manufacturer
9017073	Power Analyser(DEWETRON)	DEWE2-PA7	Austria, DEWETRON
9017078	Programmable AC Source(61860)	61860	Chroma ATE INC.
G1819268	Anti-islanding test detection devices	ACLT-4830H	QUNLING Energy Resources
G1819272	Leakage Current Testing Network	IEC 60990, Figure 4	Shanghai Anbiao Co., Ltd.
G1819277	PV array simulator	62150H-1000S	Chroma Co.
G1819278	PV array simulator	62150H-1000S	Chroma Co.
G1819279	PV array simulator	62150H-1000S	Chroma Co.
G1819280	PV array simulator	62150H-1000S	Chroma Co.

Prüfbericht-Nr.: CN2283DK 003
Test Report No.:


Seite 3 von 23
Page 3 of 23

Produktbeschreibung
Product description


1 **Produktdetails**
Product details

See below.

Copy of marking plate:






Product Name	Grid-connected PV inverter
Model	APEX-P3-3000
Max. DC Input Power	3.9kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max.DC Input Current	2x13Adc
Max. short circuit input current	2x19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	3kW
Max. Active Power	3.3kW
Max. Apparent Output Power	3.3kVA
Max. AC Output Current	4.8Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I
Standard	IEC/EN 62109-1, IEC/EN 62109-2





Apex Solar Energy Technology GmbH
Add: Reisholzer Werftstr. 76, Düsseldorf,
40589 Germany


Safety Warning


  The AC and DC circuits must be disconnected separately, and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.

 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.


 Surface high temperature , Please do not touch the inverter case.

 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.






Product Name	Grid-connected PV inverter
Model	APEX-P3-3000-G
Max. DC Input Power	3.9kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max.DC Input Current	2x20Adc
Max. short circuit input current	2x30Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	3kW
Max. Active Power	3.3kW
Max. Apparent Output Power	3.3kVA
Max. AC Output Current	4.8Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I
Standard	IEC/EN 62109-1, IEC/EN 62109-2





Apex Solar Energy Technology GmbH
Add: Reisholzer Werftstr. 76, Düsseldorf,
40589 Germany


Safety Warning

  The AC and DC circuits must be disconnected separately, and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.









 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.









 Surface high temperature , Please do not touch the inverter case.

 The DC input terminals of the inverter must not be grounded.


 Please read the instructions carefully before use.

Produktbeschreibung
Product description

	
Product Name	Grid-connected PV Inverter
Model	APEX-P3-4000
Max. DC Input Power	5.2KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max. DC Input Current	2×13Adc
Max. short circuit input current	2×19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	4kW
Max. Active Power	4.4kW
Max. Apparent Output Power	4.4kVA
Max. AC Output Current	6.4Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I
Standard	IEC/EN 62109-1, IEC/EN 62109-2
	
Apex Solar Energy Technology GmbH Add: Reisholzer Werftstr. 76, Düsseldorf, 40589 Germany	
Safety Warning	
<p>  The AC and DC circuits must be disconnected separately; 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.</p> <p> It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.</p> <p> Surface high temperature . Please do not touch the inverter case.</p> <p> The DC input terminals of the inverter must not be grounded.</p> <p> Please read the instructions carefully before use.</p>	


	
Product Name	Grid-connected PV Inverter
Model	APEX-P3-4000-G
Max. DC Input Power	5.2KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max. DC Input Current	2×20Adc
Max. short circuit input current	2×30Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	4kW
Max. Active Power	4.4kW
Max. Apparent Output Power	4.4kVA
Max. AC Output Current	6.4Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I
Standard	IEC/EN 62109-1, IEC/EN 62109-2
	
Apex Solar Energy Technology GmbH Add: Reisholzer Werftstr. 76, Düsseldorf, 40589 Germany	
Safety Warning	
<p>  The AC and DC circuits must be disconnected separately; 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.</p> <p> It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.</p> <p> Surface high temperature . Please do not touch the inverter case.</p> <p> The DC input terminals of the inverter must not be grounded.</p> <p> Please read the instructions carefully before use.</p>	

Produktbeschreibung
Product description





Product Name	Grid-connected PV inverter
Model	APEX-P3-5000
Max. DC Input Power	6.5KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max.DC Input Current	2x13Adc
Max. short circuit input current	2x19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	5kW
Max. Active Power	5.5kW
Max. Apparent Output Power	5.5kVA
Max. AC Output Current	8Aac
Power Factor	-0.8 – +0.8
Operating Temperature Range	-25°C – +65°C
Ingress Protection	IP65
Protection Level	Class I


Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------





Apex Solar Energy Technology GmbH
Add: **Reisholzer Wertstr. 76, Düsseldorf, 40589 Germany**


Safety Warning


  The AC and DC circuits must be disconnected separately. *5min* and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.

 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature . Please do not touch the inverter case.


 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.





Product Name	Grid-connected PV inverter
Model	APEX-P3-5000-G
Max. DC Input Power	6.5KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max.DC Input Current	2x20Adc
Max. short circuit input current	2x30Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	5kW
Max. Active Power	5.5kW
Max. Apparent Output Power	5.5kVA
Max. AC Output Current	8Aac
Power Factor	-0.8 – +0.8
Operating Temperature Range	-25°C – +65°C
Ingress Protection	IP65
Protection Level	Class I


Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------





Apex Solar Energy Technology GmbH
Add: **Reisholzer Wertstr. 76, Düsseldorf, 40589 Germany**


Safety Warning

  The AC and DC circuits must be disconnected separately. *5min* and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.


 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature . Please do not touch the inverter case.

 The DC input terminals of the inverter must not be grounded.


 Please read the instructions carefully before use.

Produktbeschreibung
Product description





Product Name	Grid-connected PV inverter
Model	APEX-P3-6000
Max. DC Input Power	7.8kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max. DC Input Current	2x13Adc
Max. short circuit input current	2x19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	6kW
Max. Active Power	6.6kW
Max. Apparent Output Power	6.6kVA
Max. AC Output Current	9.6Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I


Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------





Apex Solar Energy Technology GmbH
Add: Reisholzer Werfstr. 76, Düsseldorf,
40585 Germany


Safety Warning


  The AC and DC circuits must be disconnected separately. 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.

 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature . Please do not touch the inverter case.


 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.





Product Name	Grid-connected PV inverter
Model	APEX-P3-6000-G
Max. DC Input Power	7.8kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max. DC Input Current	2x20Adc
Max. short circuit input current	2x30Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	6kW
Max. Active Power	6.6kW
Max. Apparent Output Power	6.6kVA
Max. AC Output Current	9.6Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I


Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------





Apex Solar Energy Technology GmbH
Add: Reisholzer Werfstr. 76, Düsseldorf,
40585 Germany


Safety Warning

  The AC and DC circuits must be disconnected separately. 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.


 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature . Please do not touch the inverter case.


 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.

Produktbeschreibung
Product description






Product Name	Grid-connected PV Inverter
Model	APEX-P3-7000
Max. DC Input Power	9.1kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max. DC Input Current	2x13Adc
Max. short circuit input current	2x19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	7kW
Max. Active Power	7.7kW
Max. Apparent Output Power	7.7kVA
Max. AC Output Current	11.1Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I
Standard	IEC/EN 62109-1, IEC/EN 62109-2





Apex Solar Energy Technology GmbH
Add: Reisholzer Wertstr. 76, Düsseldorf,
40589 Germany


Safety Warning


  The AC and DC circuits must be disconnected separately, 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.

 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.


 Surface high temperature , Please do not touch the inverter case.

 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.






Product Name	Grid-connected PV Inverter
Model	APEX-P3-7000-G
Max. DC Input Power	9.1kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max. DC Input Current	2x20Adc
Max. short circuit input current	2x30Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	7kW
Max. Active Power	7.7kW
Max. Apparent Output Power	7.7kVA
Max. AC Output Current	11.1Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I
Standard	IEC/EN 62109-1, IEC/EN 62109-2





Apex Solar Energy Technology GmbH
Add: Reisholzer Wertstr. 76, Düsseldorf,
40589 Germany


Safety Warning

  The AC and DC circuits must be disconnected separately, 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.


 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature , Please do not touch the inverter case.

 The DC input terminals of the inverter must not be grounded.


 Please read the instructions carefully before use.

Produktbeschreibung
Product description





Product Name	Grid-connected PV inverter
Model	APEX-P3-8000
Max. DC Input Power	10.4KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max.DC Input Current	2x13Adc
Max. short circuit input current	2x19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	8kW
Max. Active Power	8.8kW
Max. Apparent Output Power	8.8kVA
Max. AC Output Current	12.8Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I


Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------





Apex Solar Energy Technology GmbH
Add: Reisholzer Werftstr. 76, Düsseldorf,
40589 Germany


Safety Warning


  The AC and DC circuits must be disconnected separately. SMITH and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.

 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature , Please do not touch the inverter case.


 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.





Product Name	Grid-connected PV inverter
Model	APEX-P3-8000-G
Max. DC Input Power	10.4KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max.DC Input Current	2x20Adc
Max. short circuit input current	2x30Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	8kW
Max. Active Power	8.8kW
Max. Apparent Output Power	8.8kVA
Max. AC Output Current	12.8Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I


Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------





Apex Solar Energy Technology GmbH
Add: Reisholzer Werftstr. 76, Düsseldorf,
40589 Germany


Safety Warning

  The AC and DC circuits must be disconnected separately. SMITH and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.


 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature , Please do not touch the inverter case.


 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.

Produktbeschreibung
Product description






Product Name	Grid-connected PV inverter
Model	APEX-P3-9000
Max. DC Input Power	11.7kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max.DC Input Current	2x13Adc
Max. short circuit input current	2x19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	9kW
Max. Active Power	9.9kW
Max. Apparent Output Power	9.9kVA
Max. AC Output Current	14.3Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I
Standard	IEC/EN 62109-1, IEC/EN 62109-2





Apex Solar Energy Technology GmbH
Add: Reisholzer Wertstr. 76, Düsseldorf,
40589 Germany


Safety Warning


  The AC and DC circuits must be disconnected separately, 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.

 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.


 Surface high temperature , Please do not touch the inverter case.

 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.






Product Name	Grid-connected PV inverter
Model	APEX-P3-9000-G
Max. DC Input Power	11.7kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max.DC Input Current	2x20Adc
Max. short circuit input current	2x30Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	9kW
Max. Active Power	9.9kW
Max. Apparent Output Power	9.9kVA
Max. AC Output Current	14.3Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I
Standard	IEC/EN 62109-1, IEC/EN 62109-2





Apex Solar Energy Technology GmbH
Add: Reisholzer Wertstr. 76, Düsseldorf,
40589 Germany


Safety Warning

  The AC and DC circuits must be disconnected separately, 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.


 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature , Please do not touch the inverter case.

 The DC input terminals of the inverter must not be grounded.


 Please read the instructions carefully before use.

Produktbeschreibung
Product description





Product Name	Grid-connected PV Inverter
Model	APEX-P3-10K
Max. DC Input Power	13kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max. DC Input Current	2×13Adc
Max. short circuit input current	2×19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	10kW
Max. Active Power	11kW
Max. Apparent Output Power	11kVA
Max. AC Output Current	15.9Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I

Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------




Apex Solar Energy Technology GmbH
Add: Reisholzer Werftstr. 76, Düsseldorf,
40589 Germany


Safety Warning


The AC and DC circuits must be disconnected separately. 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.




It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.




Surface high temperature , Please do not touch the inverter case.



The DC input terminals of the inverter must not be grounded.




Please read the instructions carefully before use.





Product Name	Grid-connected PV Inverter
Model	APEX-P3-10K-G
Max. DC Input Power	13kW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	120-850Vdc
Max. DC Input Current	2×20Adc
Max. short circuit input current	2×30Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	10kW
Max. Active Power	11kW
Max. Apparent Output Power	11kVA
Max. AC Output Current	15.9Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I

Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------




Apex Solar Energy Technology GmbH
Add: Reisholzer Werftstr. 76, Düsseldorf,
40589 Germany


Safety Warning


The AC and DC circuits must be disconnected separately. 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.




It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.



Surface high temperature , Please do not touch the inverter case.




The DC input terminals of the inverter must not be grounded.




Please read the instructions carefully before use.

Produktbeschreibung
Product description





Product Name	Grid-connected PV inverter
Model	APEX-P3-12K
Max. DC Input Power	15.6KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	200-850Vdc
Max. DC Input Current	2×13Adc
Max. short circuit input current	2×19.5Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	12kW
Max. Active Power	13.2KW
Max. Apparent Output Power	13.2KVA
Max. AC Output Current	19.1Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I

Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------




Apex Solar Energy Technology GmbH
Add: Reisholzer Werfstr. 76, Düsseldorf,
40589 Germany


Safety Warning


The AC and DC circuits must be disconnected separately. 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.




It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.




Surface high temperature , Please do not touch the inverter case.



The DC input terminals of the inverter must not be grounded.




Please read the instructions carefully before use.





Product Name	Grid-connected PV inverter
Model	APEX-P3-12K-G
Max. DC Input Power	15.6KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	200-850Vdc
Max. DC Input Current	2×20Adc
Max. short circuit input current	2×30dc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	12kW
Max. Active Power	13.2KW
Max. Apparent Output Power	13.2KVA
Max. AC Output Current	19.1Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I

Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------




Apex Solar Energy Technology GmbH
Add: Reisholzer Werfstr. 76, Düsseldorf,
40589 Germany


Safety Warning


The AC and DC circuits must be disconnected separately. 5min and the maintenance personnel must wait for 5 minutes before they are completely powered off before they can start working.




It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.



Surface high temperature , Please do not touch the inverter case.




The DC input terminals of the inverter must not be grounded.




Please read the instructions carefully before use.

Produktbeschreibung
Product description





Product Name	Grid-connected PV inverter
Model	APEX-P3-15K
Max. DC Input Power	19.5KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	200-850Vdc
Max. DC Input Current	13+26Adc
Max. short circuit input current	19.5+39Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	15kW
Max. Active Power	16.5KW
Max. Apparent Output Power	16.5KVA
Max. AC Output Current	23.9Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I


Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------





Apex Solar Energy Technology GmbH
Add: Reshalzer Werfstr. 76, Düsseldorf,
40589 Germany


Safety Warning


  The AC and DC circuits must be disconnected separately, and the maintenance personnel must wait for 3 minutes before they are completely powered off before they can start working.

 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature , Please do not touch the inverter case.


 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.





Product Name	Grid-connected PV inverter
Model	APEX-P3-15K-G
Max. DC Input Power	19.5KW
Max. DC Input Voltage	1000Vdc
MPPT Voltage Range	200-850Vdc
Max. DC Input Current	20+26Adc
Max. short circuit input current	30+39Adc
Rated AC Grid Voltage	3L/N/PE 230/400V
Rated AC Grid Frequency	50/60Hz
Rated AC Output Power	15kW
Max. Active Power	16.5KW
Max. Apparent Output Power	16.5KVA
Max. AC Output Current	23.9Aac
Power Factor	-0.8~+0.8
Operating Temperature Range	-25°C~+65°C
Ingress Protection	IP65
Protection Level	Class I


Standard	IEC/EN 62109-1, IEC/EN 62109-2
----------	-----------------------------------





Apex Solar Energy Technology GmbH
Add: Reshalzer Werfstr. 76, Düsseldorf,
40589 Germany


Safety Warning

  The AC and DC circuits must be disconnected separately, and the maintenance personnel must wait for 3 minutes before they are completely powered off before they can start working.

 It is strictly forbidden for users to open the casing. Professional maintenance is required for internal maintenance of the inverter.

 Surface high temperature , Please do not touch the inverter case.

 The DC input terminals of the inverter must not be grounded.

 Please read the instructions carefully before use.

Prüfbericht-Nr.: CN2283DK 003
Test Report No.:

Seite 13 von 23
Page 13 of 23

Produktbeschreibung
Product description

Possible test case verdicts:


- test case does not apply to the test object..... : N/A
- test object was not evaluated for the requirement.... : N/E
- test object does meet the requirement : Pass (P)
- test object does not meet the requirement..... : Fail (F)

Testing:

Date of receipt of test items..... : See cover page
Date(s) of performance of tests..... : See cover page

General remarks:

"(see Attachment #)" refers to additional information appended to the report.
"(see appended table)" refers to a table appended to the report.
The tests results presented in this report relate only to the object tested.
This report shall not be reproduced except in full without the written approval of the testing laboratory.
List of test equipment must be kept on file and available for review.
Additional test data and/or information provided in the attachments to this report.
Throughout this report a comma / point is used as the decimal separator.
Generator reference system:




General product information:

Breif description:

The on-grid inverter is designed according to the wall mounted type installation , can convert solar panel DC power into AC power which can directly input to the grid. The block diagram below shows the topologic structure of it.

Produktbeschreibung
Product description



Block Diagram

Model Difference:

The inverters: APEX-P3-xx(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K), APEX-P3-xx-G(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K) are identical, they used the same PCB Layout, the difference between them are showed in the table below.

Prüfbericht-Nr.: CN2283DK 003
Test Report No.:

Seite 15 von 23
Page 15 of 23

Produktbeschreibung
Product description

Reference Position	APEX-P3-xx(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K)	APEX-P3-12K	APEX-P3-15K	Comments
L1,L2,LR,LS,LT	10KW-(L1+L2+LR+LS+LT)	12KW-(L1+L2+LR+LS+LT)	15KW-(L1+L2+LR+LS+LT)	Inverter Choke
C141,C142	500V/390uF	NC	NC	Inverter Bus Capacitor
C1,C2,C3,C4	NC	600V/50uF	600V/50uF	
D1	1200V/60A	1200V/60A	1200V/60A	Freewheeling Diode
D23	1200V/60A	1200V/60A	1200V/20A-SIC	
R109, R25, R110, R42	2.2K	2.2K	3.3K	Inverter current sampling resistor
FAN1	12V/0.31A/60mm	12V/0.31A/60mm	12V/0.31A/60mm	Internal fan
FAN2	NC	NC	12V/0.3A/80mm	External fan
PV input connector in parallel	2/1+1	2/1+1	2/1+2	Number of input connectors

Throughout the test report following abbreviations may be used:

- | | | | |
|-------|-----------------------------|-------|--------------------------|
| • cl | clearance | • s-c | short-circuit |
| • dcr | creepage distance | • o-c | open-circuit |
| • dti | distance through insulation | • o-l | overload |
| • BI | basic insulation | • SI | supplementary insulation |
| • DI | double insulation | • RI | reinforced insulation |

Remote control:

Remote shutdown and power control function is realized by Meter or Wifi interface.

The product was tested on:

Software version: 5172

Test condition:

Temperature: 25°C Relative humidity: 65%

Produktbeschreibung
Product description

Model list:

MODELS LIST		APEX-P3-3000	APEX-P3-4000	APEX-P3-5000
PV INPUT	$V_{MAX\ PV}$ [Vdc]	1000		
	$I_{SC\ PV}$ [A]	19.5/19.5	19.5/19.5	19.5/19.5
	MPP Voltage Range V_{MPP} [Vdc]	120-850	120-850	120-850
	Max. Input Current I_{MAX} [A]	13.0/13.0	13.0/13.0	13.0/13.0
AC OUTPUT	Rated Output Voltage per phase U_n [Vac]	3L/N/PE 400		
	Rated Output Frequency f_n [Hz]	50		
	Rated Active Power P_n [W]	3000	4000	5000
	Max. Active Power $P_{E_{max}}$ [W]	3300	4400	5500
	Max. Apparent power $S_{E_{max}}$ [VA]	3300	4400	5500
	Max. Output Current I_{max} [A]	4.8	6.4	8.0
	Power Factor Range $\cos\phi$ [λ]	0.8un...0.8ov		
ROTECTION SETTINGS	Firmware version	5172		
	Voltage threshold value [U/Un]	$U_{MIN\ stage\ 1}: 0.80, U_{MIN\ stage\ 2}: 0.45$ $U_{MAX\ stage\ 1}: 1.10, U_{MAX\ stage\ 2}: 1.25$		
	The accuracy of voltage measurement [U/Un]	± 0.01		
	Voltage trip time [ms]	$U_{MIN\ stage\ 1}: <3100 (T_{LIMIT}: <3100),$ $U_{MIN\ stage\ 2}: <400 (T_{LIMIT}: <400),$ $U_{MAX\ stage\ 1}: <200 (T_{LIMIT}: <200),$ $U_{MAX\ stage\ 2}: <200 (T_{LIMIT}: <200)$		
	Frequency threshold value [Hz]	$F_{MIN}: 47.5, F_{MAX}: 51.5$		
	The accuracy of frequency measurement [f/fn]	± 0.001		
	Frequency trip time [ms]	$F_{MIN}: <200 (T_{LIMIT}: 200), F_{MAX}: <200 (T_{LIMIT}: 200)$		
	Active anti-islanding trip time [s]	$<9.0 (T_{LIMIT}: 9)$		
	Reconnection Voltage [U/Un]	$U_{MIN}: 0.85, U_{MAX}: 1.10$		
	Reconnection Frequency [Hz]	$F_{MIN}: 47.5 (F_{LIMITU}: 47.5),$ $F_{MAX}: 50.10 (F_{LIMITO}: 50.10)$		
	Reconnection Time [s]	$60 (T_{LIMIT} \geq 60)$		

Note*:

Produktbeschreibung
Product description

MODELS LIST		APEX-P3-6000	APEX-P3-7000	APEX-P3-8000	APEX-P3-9000
PV INPUT	$V_{MAX\ PV}$ [Vdc]	1000			
	$I_{SC\ PV}$ [A]	19.5/19.5	19.5/19.5	19.5/19.5	19.5/19.5
	MPP Voltage Range V_{MPP} [Vdc]	120-850	120-850	120-850	120-850
	Max. Input Current I_{MAX} [A]	13.0/13.0	13.0/13.0	13.0/13.0	13.0/13.0
AC OUTPUT	Rated Output Voltage per phase U_n [Vac]	3L/N/PE 400			
	Rated Output Frequency f_n [Hz]	50			
	Rated Active Power P_n [W]	6000	7000	8000	9000
	Max. Active Power $P_{E_{max}}$ [W]	6600	7700	8800	9900
	Max. Apparent power $S_{E_{max}}$ [VA]	6600	7700	8800	9900
	Max. Output Current I_{max} [A]	9.6	11.1	12.8	14.3
	Power Factor Range $\cos\phi$ [λ]	0.8un...0.8ov			
ROTECTION SETTINGS	Firmware version	5172			
	Voltage threshold value [U/ U_n]	$U_{MIN\ stage\ 1}: 0.80, U_{MIN\ stage\ 2}: 0.45$ $U_{MAX\ stage\ 1}: 1.10, U_{MAX\ stage\ 2}: 1.25$			
	The accuracy of voltage measurement[U/ U_n]	± 0.01			
	Voltage trip time [ms]	$U_{MIN\ stage\ 1}: <3100 (T_{LIMIT}: <3100),$ $U_{MIN\ stage\ 2}: <400 (T_{LIMIT}: <400),$ $U_{MAX\ stage\ 1}: <200 (T_{LIMIT}: <200),$ $U_{MAX\ stage\ 2}: <200 (T_{LIMIT}: <200)$			
	Frequency threshold value [Hz]	$F_{MIN}: 47.5, F_{MAX}: 51.5$			
	The accuracy of frequency measurement [f/ f_n]	± 0.001			
	Frequency trip time [ms]	$F_{MIN}: <200 (T_{LIMIT}: 200), F_{MAX}: <200 (T_{LIMIT}: 200)$			
	Active anti-islanding trip time [s]	$<9.0 (T_{LIMIT}: 9)$			
	Reconnection Voltage [U/ U_n]	$U_{MIN}: 0.85, U_{MAX}: 1.10$			
	Reconnection Frequency [Hz]	$F_{MIN}: 47.5 (F_{LIMITU}: 47.5),$ $F_{MAX}: 50.10 (F_{LIMITO}: 50.10)$			
	Reconnection Time [s]	$60 (T_{LIMIT} \geq 60)$			

Note*:

Produktbeschreibung
Product description

MODELS LIST		APEX-P3-10K	APEX-P3-12K	APEX-P3-15K
PV INPUT	$V_{MAX\ PV}$ [Vdc]	1000		
	$I_{SC\ PV}$ [A]	19.5/19.5	19.5/19.5	19.5/39.0
	MPP Voltage Range V_{MPP} [Vdc]	120-850	200-850	200-850
	Max. Input Current I_{MAX} [A]	13.0/13.0	13.0/13.0	13.0/26.0
AC OUTPUT	Rated Output Voltage per phase U_n [Vac]	3L/N/PE 400		
	Rated Output Frequency F_n [Hz]	50		
	Rated Active Power P_n [W]	10000	12000	15000
	Max. Active Power $P_{E_{max}}$ [W]	11000	13200	16500
	Max. Apparent power $S_{E_{max}}$ [VA]	11000	13200	16500
	Max. Output Current I_{max} [A]	15.9	19.1	23.9
	Power Factor Range $\cos\phi$ [λ]	0.8un...0.8ov		
ROTECTION SETTINGS	Firmware version	5172		
	Voltage threshold value [U/Un]	$U_{MIN\ stage\ 1}: 0.80, U_{MIN\ stage\ 2}: 0.45$ $U_{MAX\ stage\ 1}: 1.10, U_{MAX\ stage\ 2}: 1.25$		
	The accuracy of voltage measurement[U/Un]	± 0.01		
	Voltage trip time [ms]	$U_{MIN\ stage\ 1}: <3100 (T_{LIMIT}: <3100),$ $U_{MIN\ stage\ 2}: <400 (T_{LIMIT}: <400),$ $U_{MAX\ stage\ 1}: <200 (T_{LIMIT}: <200),$ $U_{MAX\ stage\ 2}: <200 (T_{LIMIT}: <200)$		
	Frequency threshold value [Hz]	$F_{MIN}: 47.5, F_{MAX}: 51.5$		
	The accuracy of frequency measurement [f/fn]	± 0.001		
	Frequency trip time [ms]	$F_{MIN}: <200 (T_{LIMIT}: 200), F_{MAX}: <200 (T_{LIMIT}: 200)$		
	Active anti-islanding trip time [s]	$<9.0 (T_{LIMIT}: 9)$		
	Reconnection Voltage [U/Un]	$U_{MIN}: 0.85, U_{MAX}: 1.10$		
	Reconnection Frequency [Hz]	$F_{MIN}: 47.5 (F_{LIMITU}: 47.5),$ $F_{MAX}: 50.10 (F_{LIMITO}: 50.10)$		
Reconnection Time [s]	$60 (T_{LIMIT} \geq 60)$			

Note*:

Produktbeschreibung
Product description

MODELS LIST		APEX-P3-3000-G	APEX-P3-4000-G	APEX-P3-5000-G
PV INPUT	$V_{MAX\ PV}$ [Vdc]	1000		
	$I_{SC\ PV}$ [A]	30.0/30.0	30.0/30.0	30.0/30.0
	MPP Voltage Range V_{MPP} [Vdc]	120-850	120-850	120-850
	Max. Input Current I_{MAX} [A]	20.0/20.0	20.0/20.0	20.0/20.0
AC OUTPUT	Rated Output Voltage per phase U_n [Vac]	3L/N/PE 400		
	Rated Output Frequency f_n [Hz]	50		
	Rated Active Power P_n [W]	3000	4000	5000
	Max. Active Power $P_{E_{max}}$ [W]	3300	4400	5500
	Max. Apparent power $S_{E_{max}}$ [VA]	3300	4400	5500
	Max. Output Current I_{max} [A]	4.8	6.4	8.0
	Power Factor Range $\cos\phi$ [λ]	0.8un...0.8ov		
ROTECTION SETTINGS	Firmware version	5172		
	Voltage threshold value [U/Un]	$U_{MIN\ stage\ 1}: 0.80, U_{MIN\ stage\ 2}: 0.45$ $U_{MAX\ stage\ 1}: 1.10, U_{MAX\ stage\ 2}: 1.25$		
	The accuracy of voltage measurement[U/Un]	± 0.01		
	Voltage trip time [ms]	$U_{MIN\ stage\ 1}: <3100 (T_{LIMIT}: <3100),$ $U_{MIN\ stage\ 2}: <400 (T_{LIMIT}: <400),$ $U_{MAX\ stage\ 1}: <200 (T_{LIMIT}: <200),$ $U_{MAX\ stage\ 2}: <200 (T_{LIMIT}: <200)$		
	Frequency threshold value [Hz]	$F_{MIN}: 47.5, F_{MAX}: 51.5$		
	The accuracy of frequency measurement [f/fn]	± 0.001		
	Frequency trip time [ms]	$F_{MIN}: <200 (T_{LIMIT}: 200), F_{MAX}: <200 (T_{LIMIT}: 200)$		
	Active anti-islanding trip time [s]	$<9.0 (T_{LIMIT}: 9)$		
	Reconnection Voltage [U/Un]	$U_{MIN}: 0.85, U_{MAX}: 1.10$		
	Reconnection Frequency [Hz]	$F_{MIN}: 47.5 (F_{LIMITU}: 47.5),$ $F_{MAX}: 50.10 (F_{LIMITO}: 50.10)$		
Reconnection Time [s]	$60 (T_{LIMIT} \geq 60)$			

Note*:

Produktbeschreibung
Product description

MODELS LIST		APEX-P3-6000-G	APEX-P3-7000-G	APEX-P3-8000-G	APEX-P3-9000-G
PV INPUT	$V_{MAX\ PV}$ [Vdc]	1000			
	$I_{SC\ PV}$ [A]	30.0/30.0	30.0/30.0	30.0/30.0	30.0/30.0
	MPP Voltage Range V_{MPP} [Vdc]	120-850	120-850	120-850	120-850
	Max. Input Current I_{MAX} [A]	20.0/20.0	20.0/20.0	20.0/20.0	20.0/20.0
AC OUTPUT	Rated Output Voltage per phase U_n [Vac]	3L/N/PE 400			
	Rated Output Frequency F_n [Hz]	50			
	Rated Active Power P_n [W]	6000	7000	8000	9000
	Max. Active Power $P_{E_{max}}$ [W]	6600	7700	8800	9900
	Max. Apparent power $S_{E_{max}}$ [VA]	6600	7700	8800	9900
	Max. Output Current I_{max} [A]	9.6	11.1	12.8	14.3
	Power Factor Range $\cos\phi$ [λ]	0.8un...0.8ov			
ROTECTION SETTINGS	Firmware version	5172			
	Voltage threshold value [U/ U_n]	$U_{MIN\ stage\ 1}$: 0.80, $U_{MIN\ stage\ 2}$: 0.45 $U_{MAX\ stage\ 1}$: 1.10, $U_{MAX\ stage\ 2}$: 1.25			
	The accuracy of voltage measurement[U/ U_n]	± 0.01			
	Voltage trip time [ms]	$U_{MIN\ stage\ 1}$: <3100 (T_{LIMIT} : <3100), $U_{MIN\ stage\ 2}$: <400 (T_{LIMIT} : <400), $U_{MAX\ stage\ 1}$: <200 (T_{LIMIT} : <200), $U_{MAX\ stage\ 2}$: <200 (T_{LIMIT} : <200)			
	Frequency threshold value [Hz]	F_{MIN} : 47.5, F_{MAX} : 51.5			
	The accuracy of frequency measurement [f/ f_n]	± 0.001			
	Frequency trip time [ms]	F_{MIN} : <200 (T_{LIMIT} : 200), F_{MAX} : <200 (T_{LIMIT} : 200)			
	Active anti-islanding trip time [s]	<9.0 (T_{LIMIT} : 9)			
	Reconnection Voltage [U/ U_n]	U_{MIN} : 0.85, U_{MAX} : 1.10			
	Reconnection Frequency [Hz]	F_{MIN} : 47.5 (F_{LIMITU} : 47.5), F_{MAX} : 50.10 (F_{LIMITO} : 50.10)			
Reconnection Time [s]	60 ($T_{LIMIT} \geq 60$)				

Note*:

Prüfbericht-Nr.: CN2283DK 003
Test Report No.:

Seite 21 von 23
Page 21 of 23

Produktbeschreibung
Product description

MODELS LIST		APEX-P3-10K-G	APEX-P3-12K-G	APEX-P3-15K-G
PV INPUT	$V_{MAX\ PV}$ [Vdc]	1000		
	$I_{SC\ PV}$ [A]	30.0/30.0	30.0/30.0	30.0/39.0
	MPP Voltage Range V_{MPP} [Vdc]	120-850	200-850	200-850
	Max. Input Current I_{MAX} [A]	20.0/20.0	20.0/20.0	20.0/26.0
AC OUTPUT	Rated Output Voltage per phase U_n [Vac]	3L/N/PE 400		
	Rated Output Frequency f_n [Hz]	50		
	Rated Active Power P_n [W]	10000	12000	15000
	Max. Active Power $P_{E_{max}}$ [W]	11000	13200	16500
	Max. Apparent power $S_{E_{max}}$ [VA]	11000	13200	16500
	Max. Output Current I_{max} [A]	15.9	19.1	23.9
	Power Factor Range $\cos\phi$ [λ]	0.8un...0.8ov		
ROTECTION SETTINGS	Firmware version	5172		
	Voltage threshold value [U/Un]	$U_{MIN\ stage\ 1}: 0.80, U_{MIN\ stage\ 2}: 0.45$ $U_{MAX\ stage\ 1}: 1.10, U_{MAX\ stage\ 2}: 1.25$		
	The accuracy of voltage measurement[U/Un]	± 0.01		
	Voltage trip time [ms]	$U_{MIN\ stage\ 1}: <3100 (T_{LIMIT}: <3100),$ $U_{MIN\ stage\ 2}: <400 (T_{LIMIT}: <400),$ $U_{MAX\ stage\ 1}: <200 (T_{LIMIT}: <200),$ $U_{MAX\ stage\ 2}: <200 (T_{LIMIT}: <200)$		
	Frequency threshold value [Hz]	$F_{MIN}: 47.5, F_{MAX}: 51.5$		
	The accuracy of frequency measurement [f/fn]	± 0.001		
	Frequency trip time [ms]	$F_{MIN}: <200 (T_{LIMIT}: 200), F_{MAX}: <200 (T_{LIMIT}: 200)$		
	Active anti-islanding trip time [s]	$<9.0 (T_{LIMIT}: 9)$		
	Reconnection Voltage [U/Un]	$U_{MIN}: 0.85, U_{MAX}: 1.10$		
	Reconnection Frequency [Hz]	$F_{MIN}: 47.5 (F_{LIMITU}: 47.5),$ $F_{MAX}: 50.10 (F_{LIMITO}: 50.10)$		
	Reconnection Time [s]	$60 (T_{LIMIT} \geq 60)$		
Note*:				

Prüfbericht-Nr.: CN2283DK 003
Test Report No.:

Seite 22 von 23
Page 22 of 23

Produktbeschreibung
Product description

2	Maße / Gewicht <i>Dimensions / Weight</i>	Please refer to the user manual.
3	Bedienelemente <i>Operating elements</i>	N/A
4	Ausstattung / Zubehör <i>Equipment / Accessories</i>	N/A
5	Verwendete Materialien <i>Used materials</i>	N/A
6	Sonstiges <i>Other</i>	N/A

1	<p>Anwendungsbereich Scope</p> <p>Details zur Ausgestaltung der messtechnischen Nachweise und zur Dokumentation der Messergebnisse sind in DIN VDE-V 0124-100 (VDE V 0124-100):2020-06 beschrieben.</p> <p><i>Details on the design of the measuring certificates and the documentation of the measurement results are described in DIN VDE-V 0124-100 (VDE V 0124-100):2020-06.</i></p>
----------	---

ANLAGE zum Prüfbericht-Nr.: CN2283DK 003
APPENDIX to Test Report No.:

Seite 23 von 23
Page 23 of 23

ZUSATZ-DOKUMENTATION
ADDITIONAL DOCUMENTATION

See CN2283DK 003 attachment 1 for test report of VDE V 0124-100: 2020.
See CN2283DK 003 attachment 2 for Photo documentations

Prüfbericht-Nr.: <i>Test report no.:</i>	See test report CN2283DK 003	Auftrags-Nr.: <i>Order no.:</i>	See test report CN2283DK 003	Seite 1 von 5 Page 1 of 5
Kunden-Referenz-Nr.: <i>Client reference no.:</i>	See test report CN2283DK 003	Auftragsdatum: <i>Order date:</i>	See test report CN2283DK 003	
Auftraggeber: <i>Client:</i>	See test report CN2283DK 003			
Prüfgegenstand: <i>Test item:</i>	See test report CN2283DK 003			
Bezeichnung / Typ-Nr.: <i>Identification / Type no.:</i>	See test report CN2283DK 003			
Auftrags-Inhalt: <i>Order content:</i>	A3 Certificate			
Prüfgrundlage: <i>Test specification:</i>	<p>DIN VDE V 0124-100/06.20</p> <p><i>Netzintegration von Erzeugungsanlagen –Niederspannung –Prüfanforderungen an Erzeugungseinheiten vorgesehen zum Anschluss und Parallelbetrieb am Niederspannungsnetz</i></p> <p><i>Grid integration of generator plants – Low-voltage – Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks</i></p>			
Wareneingangsdatum: <i>Date of sample receipt:</i>	See test report CN2283DK 003			
Prüfmuster-Nr.: <i>Test sample no.:</i>	See test report CN2283DK 003			
Prüfzeitraum: <i>Testing period:</i>	See test report CN2283DK 003			
Ort der Prüfung: <i>Place of testing:</i>	See test report CN2283DK 003			
Prüflaboratorium: <i>Testing laboratory:</i>	See test report CN2283DK 003			
Prüfergebnis*: <i>Test result*:</i>	Pass			
geprüft von: <i>tested by:</i> See test report CN2283DK 003	genehmigt von: <i>authorized by:</i> See test report CN2283DK 003			
Datum: <i>Date:</i> See test report CN2283DK 003	Ausstellungsdatum: <i>Issue date:</i> See test report CN2283DK 003			
Stellung / Position: See test report CN2283DK 003	Stellung / Position: See test report CN2283DK 003			
Sonstiges / <i>Other:</i> N/A				
Zustand des Prüfgegenstandes bei Anlieferung: <i>Condition of the test item at delivery:</i>	Prüfmuster vollständig und unbeschädigt <i>Test item complete and undamaged</i>			
* Legende: P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet				
* Legend: P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested				
<p>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</p> <p><i>This test report only relates to the above mentioned test sample as. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</i></p>				

v05

Prüfbericht-Nr.: CN2283DK 003 attachment 1
Test Report No.:

Seite 2 von 5
Page 2 of 5

Liste der verwendeten Prüfmittel
List of used test equipment

See test report CN2283DK 003 for detail.

Prüfbericht-Nr.: CN2283DK 003 attachment 1
Test Report No.:

Seite 3 von 5
Page 3 of 5

Produktbeschreibung
Product description

See test report CN2283DK 003

Prüfbericht-Nr.: CN2283DK 003 attachment 1
Test Report No.:

Seite 4 von 5
Page 4 of 5

Absatz	Anforderungen-Prüfungen	Messergebnisse-Bemerkungen	Bewertung
Clause	Requirements-Tests	Measuring results-Remarks	Evaluation

1	Anwendungsbereich Scope	
	Diese DIN-VDE-Vornorm dient dem Nachweis der elektrischen Eigenschaften von Erzeugungseinheiten (EZE) nach der VDE-AR N 4105:2018-11 und gegebenenfalls anderen Netzanschlussbedingungen. <i>This DIN VDE preliminary standard serves to verify the electrical properties of power generation units (PGU) in accordance with VDE-AR N 4105:2018-11 and, if applicable, other grid connection conditions.</i>	
5	Prüfungen Tests	
5.1	Allgemeines General information	P
5.2	Nachweis zulässiger Netzurückwirkungen Verification of permitted network reaction	P
5.3	Nachweis des Symmetrieverhaltens von Umrichtern Verification of symmetry behaviour of inverter	P
5.4	Nachweis des Verhaltens der Erzeugungseinheit am Netz Verification of behaviours of PGU on grid	P
5.5	Nachweis des NA-Schutzes Verification of NS-protections	N/A
5.6	Zuschaltbedingungen und Synchronisierung Connection conditions and synchronuzation	P
5.7	Nachweis der PAV,E-überwachung Verification of PAV,E-monitoring	P
5.8	Nachweis der dynamischen Netzstützung Verifiatiion of dynamic network supporting	P

Prüfbericht-Nr.: CN2283DK 003 attachment 1
Test Report No.:

Seite 5 von 5
Page 5 of 5

ZUSATZ-DOKUMENTATION
ADDITIONAL DOCUMENTATION


See following data for details.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 1 von 199 Page 1 of 199
---	---------------------	----------------------------------


Test Engineer:	Jiayu Hu	Reviewer:	Jingge Pan
Signature:		Signature:	

Testing Location:	
Name:	TÜV Rheinland (Shanghai) Co., Ltd.
Address:	No. 177, Lane 777, Guangzhong West Road, Jing'an District, Shanghai, China

Test Sample No.:	A003402982-001
------------------	----------------

Test Condition:	Generator reference system applied in test: 
-----------------	---

Test Date:	12.01.2023-13.01.2023
------------	-----------------------

Test bench diagram: 
A network model (grid impedance simulator) only connected in test bench in flicker test (<75A condition), in the other tests the network model is bypassed.

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 2 von 199
 Page 2 of 199

Test items		Remark
5.2	Verification of permitted network reaction	Pass
5.2.2	Rapid voltage change (Kimax)	Pass
5.2.3	Flicker	Pass
5.2.4	Harmonics and Inter-harmonics (I inter, I higher)	Pass
5.2.5	Commutation notches	Pass
5.2.6	DC current feeding to network (Idc)	Pass
5.3	Verification of symmetry behaviours of inverter	Pass
5.3.2	Tests of three-phase inverter (Imbalance)	Pass
5.3.3	Symmetry operation with a symmetry device	Pass
5.4	Verification of behaviours of PGU on network	Pass
5.4.2	Measurement of active- and reactive power ranges (P&Q range)	Pass
5.4.3	Active power reduction through setting provision (P control)	Pass
5.4.4	Active power output of PGU by over-frequency (LFSM-O)	Pass
5.4.5	Active power output of ESS by over-frequency (LFSM-O)	N/A
5.4.6	Active power output of PGU by under-frequency (LFSM-U)	Pass
5.4.7	Active power output of ESS by under-frequency (LFSM-U)	N/A
5.4.8.2	Tests of reactive power / displacement factor setting accuracy (Fixed $\cos\phi$)	Pass
5.4.8.3	Tests of displacement factor- / active power character curve ($\cos\phi(P)$)	Pass
5.4.8.4	Tests of reactive power-voltage character curve (Q(U))	Pass
5.5	Verification of NS-protection	Pass
5.5.2	NS-protection	Pass
5.5.3	Central NS-protecton	N/A
5.5.4	Integrated NS-protection	Pass
5.5.6	Interface switch (Functional safety)	Pass
5.5.7	Protection devices and protection settings (OV/UV, OF/UF)	Pass
5.5.9	Constructional features of NS protection	Pass
5.5.10	Islanding detection	Pass
5.6	Connection conditions and synchronization (Reconnection)	Pass
5.7	Verification of $P_{AV,E}$ monitoring	Pass
5.8	Verification of dynamic network supporting (FVRT)	Pass

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 3 von 199 Page 3 of 199
---	---------------------	----------------------------------

5.2.2	TABLE: Rapid voltage change (Kimax)			P
Test Conditions	Measurements			Limit
	U [V]	I [A]	Ki	Ki
Starting to 50%Pn	230.3	5.9	0.51	≤ 1.2
Starting to 100% Pn	230.4	11.5	0.99	≤ 1.2
Stopping at 100% Pn	230.4	11.6	1.00	≤ 1.2
Note(s):				

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 4 von 199
 Page 4 of 199

5.2.3	TABLE: Flicker					P
L1						
Measurement	Plt	0.10				
	Limit	0.65				
	Pst	dc[%]	dmax[%]	d(t)[ms]	C _{φk}	
	1.0	3.3	4.0	500	--	
1	0.10	0.13	0.37	0	0.60	
2	0.10	0.13	0.37	0	0.60	
3	0.10	0.15	0.35	0	0.60	
4	0.10	0.15	0.37	0	0.60	
5	0.10	0.14	0.37	0	0.60	
6	0.10	0.13	0.36	0	0.60	
7	0.10	0.15	0.36	0	0.60	
8	0.10	0.12	0.35	0	0.60	
9	0.10	0.11	0.37	0	0.60	
10	0.10	0.13	0.37	0	0.60	
11	0.10	0.13	0.36	0	0.60	
12	0.10	0.12	0.36	0	0.60	
L2						
Measurement	Plt	0.16				
	Limit	0.65				
	Pst	dc[%]	dmax[%]	d(t)[ms]	C _{φk}	
	1.0	3.3	4.0	500	--	
1	0.16	0.08	0.31	0	0.96	
2	0.16	0.09	0.29	0	0.96	
3	0.16	0.10	0.31	0	0.96	
4	0.16	0.11	0.31	0	0.96	
5	0.16	0.08	0.31	0	0.96	
6	0.16	0.10	0.31	0	0.96	
7	0.16	0.08	0.31	0	0.96	
8	0.16	0.11	0.30	0	0.96	
9	0.16	0.12	0.31	0	0.96	
10	0.16	0.12	0.31	0	0.96	
11	0.16	0.12	0.31	0	0.96	
12	0.16	0.08	0.31	0	0.96	
L3						
Measurement	Plt	0.06				
	Limit	0.65				
	Pst	dc[%]	dmax[%]	d(t)[ms]	C _{φk}	
	1.0	3.3	4.0	500	--	
1	0.06	0.04	0.26	0	0.36	
2	0.06	0.04	0.26	0	0.36	

Prüfbericht-Nr.: <i>Test report no.:</i>	CN2283DK 003	Seite 5 von 199 <i>Page 5 of 199</i>
--	---------------------	---

3	0.06	0.03	0.26	0	0.36
4	0.06	0.04	0.26	0	0.36
5	0.06	0.03	0.26	0	0.36
6	0.06	0.04	0.26	0	0.36
7	0.06	0.03	0.26	0	0.36
8	0.06	0.03	0.26	0	0.36
9	0.06	0.03	0.26	0	0.36
10	0.06	0.04	0.26	0	0.36
11	0.06	0.04	0.26	0	0.36
12	0.06	0.04	0.26	0	0.36

Note(s): PGU and ESS with nominal current $\leq 75A$ (Per DIN EN 61000-3-3 / DIN EN 61000-3-11)
 $Z_{ref}=0.24+0.15j$

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 6 von 199 Page 6 of 199
---	---------------------	----------------------------------

5.2.4	TABLE: linter & lhigher											P
Harmonics												
P/P _n [%]	0	10	20	30	40	50	60	70	80	90	100	Limit
Order No.	I/In [%]											
2	0.12	0.62	0.61	0.62	0.56	0.70	0.54	0.66	0.41	0.43	0.58	9.31
3	0.01	0.06	0.09	0.17	0.26	0.16	0.51	0.24	0.22	0.22	0.25	19.83
4	0.02	0.22	0.34	0.32	0.29	0.31	0.25	0.34	0.46	0.49	0.57	3.71
5	0.03	0.25	0.08	0.95	1.31	0.51	1.87	0.68	0.73	0.76	0.81	9.83
6	0.01	0.04	0.11	0.26	0.20	0.10	0.17	0.13	0.09	0.09	0.11	2.59
7	0.08	0.45	0.53	0.87	1.09	0.34	1.17	0.85	0.47	0.53	0.59	6.64
8	0.02	0.27	0.18	0.29	0.28	0.09	0.23	0.08	0.08	0.09	0.10	1.81
9	0.00	0.03	0.08	0.12	0.11	0.09	0.19	0.13	0.12	0.12	0.14	3.45
10	0.01	0.23	0.25	0.37	0.33	0.06	0.23	0.14	0.15	0.18	0.18	1.45
11	0.02	0.61	0.66	0.18	0.28	0.29	0.21	0.25	0.57	0.75	0.95	2.84
12	0.01	0.04	0.09	0.14	0.14	0.07	0.15	0.13	0.10	0.11	0.12	1.21
13	0.01	0.10	0.83	0.57	0.37	0.37	0.22	0.18	0.35	0.53	0.71	1.81
14	0.01	0.07	0.04	0.10	0.12	0.05	0.14	0.08	0.11	0.12	0.13	1.03
15	0.00	0.07	0.08	0.09	0.07	0.09	0.12	0.11	0.08	0.08	0.09	1.29
16	0.00	0.04	0.08	0.14	0.07	0.05	0.13	0.09	0.10	0.10	0.10	0.91
17	0.01	0.35	0.22	0.57	0.48	0.36	0.22	0.17	0.10	0.18	0.30	1.14
18	0.00	0.04	0.12	0.05	0.06	0.08	0.06	0.10	0.07	0.08	0.10	0.80
19	0.01	0.26	0.03	0.37	0.47	0.26	0.21	0.20	0.11	0.08	0.13	1.02
20	0.00	0.06	0.14	0.07	0.10	0.10	0.08	0.12	0.09	0.08	0.08	0.72
21	0.00	0.04	0.07	0.09	0.07	0.08	0.07	0.09	0.07	0.08	0.09	0.92
22	0.01	0.10	0.07	0.10	0.05	0.08	0.07	0.12	0.07	0.06	0.07	0.66
23	0.02	0.13	0.16	0.11	0.19	0.14	0.27	0.30	0.25	0.22	0.16	0.84
24	0.01	0.03	0.06	0.04	0.04	0.11	0.03	0.12	0.06	0.08	0.08	0.60
25	0.01	0.21	0.25	0.14	0.09	0.09	0.24	0.28	0.25	0.22	0.16	0.78
26	0.01	0.05	0.10	0.07	0.04	0.08	0.05	0.09	0.07	0.07	0.07	0.56
27	0.00	0.04	0.04	0.04	0.03	0.08	0.03	0.06	0.08	0.09	0.08	0.72
28	0.01	0.05	0.08	0.03	0.08	0.06	0.05	0.07	0.06	0.07	0.08	0.52
29	0.01	0.11	0.16	0.21	0.13	0.08	0.18	0.24	0.19	0.17	0.10	0.67
30	0.01	0.07	0.06	0.03	0.03	0.07	0.03	0.05	0.09	0.09	0.09	0.48
31	0.01	0.04	0.04	0.22	0.18	0.09	0.13	0.17	0.17	0.15	0.10	0.63
32	0.01	0.05	0.08	0.06	0.04	0.08	0.05	0.03	0.07	0.09	0.08	0.46
33	0.00	0.05	0.07	0.03	0.04	0.08	0.03	0.06	0.07	0.08	0.07	0.59
34	0.01	0.02	0.07	0.04	0.03	0.06	0.03	0.04	0.07	0.08	0.07	0.42
35	0.00	0.06	0.05	0.07	0.14	0.08	0.07	0.06	0.11	0.11	0.11	0.55
36	0.01	0.03	0.03	0.02	0.02	0.08	0.02	0.05	0.07	0.06	0.06	0.41
37	0.00	0.03	0.02	0.09	0.14	0.08	0.08	0.05	0.08	0.09	0.11	0.53
38	0.01	0.05	0.05	0.03	0.03	0.08	0.06	0.07	0.05	0.06	0.06	0.38
39	0.00	0.05	0.07	0.03	0.02	0.08	0.02	0.07	0.06	0.05	0.06	0.50
40	0.00	0.06	0.07	0.04	0.03	0.07	0.04	0.07	0.05	0.06	0.06	0.36

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 7 von 199 Page 7 of 199
---	---------------------	----------------------------------

Inter-harmonics												
P/Pn [%]	0	10	20	30	40	50	60	70	80	90	100	Limit
f [Hz]	I/In [%]											
75	0.01	0.11	0.12	0.14	0.13	0.12	0.14	0.13	0.36	0.39	0.43	--
125	0.01	0.10	0.10	0.17	0.12	0.10	0.12	0.10	0.25	0.28	0.31	--
175	0.01	0.09	0.13	0.20	0.17	0.09	0.17	0.09	0.17	0.18	0.20	--
225	0.01	0.09	0.11	0.21	0.18	0.09	0.16	0.08	0.12	0.13	0.14	--
275	0.01	0.10	0.12	0.23	0.19	0.10	0.16	0.08	0.11	0.12	0.13	--
325	0.01	0.09	0.11	0.21	0.18	0.09	0.15	0.08	0.14	0.16	0.18	--
375	0.00	0.08	0.08	0.19	0.15	0.07	0.13	0.07	0.13	0.14	0.15	--
425	0.00	0.08	0.08	0.17	0.13	0.07	0.12	0.06	0.12	0.13	0.14	--
475	0.00	0.09	0.09	0.16	0.14	0.07	0.11	0.06	0.11	0.12	0.13	--
525	0.00	0.08	0.10	0.15	0.14	0.07	0.11	0.06	0.12	0.13	0.15	--
575	0.00	0.07	0.08	0.14	0.13	0.07	0.11	0.06	0.10	0.12	0.13	--
625	0.00	0.08	0.08	0.13	0.12	0.07	0.11	0.06	0.11	0.12	0.13	--
675	0.00	0.07	0.07	0.11	0.10	0.06	0.09	0.05	0.09	0.09	0.10	--
725	0.00	0.08	0.07	0.10	0.09	0.06	0.09	0.05	0.08	0.08	0.09	--
775	0.00	0.06	0.07	0.10	0.09	0.06	0.09	0.05	0.07	0.07	0.08	--
825	0.00	0.06	0.07	0.09	0.08	0.05	0.09	0.05	0.06	0.07	0.08	--
875	0.00	0.05	0.05	0.08	0.08	0.05	0.08	0.04	0.06	0.06	0.07	--
925	0.00	0.05	0.05	0.07	0.07	0.05	0.08	0.04	0.06	0.06	0.06	--
975	0.00	0.04	0.04	0.22	0.21	0.04	0.21	0.04	0.05	0.05	0.05	--
1025	0.00	0.04	0.04	0.06	0.06	0.04	0.06	0.04	0.05	0.05	0.04	--
1075	0.00	0.04	0.06	0.06	0.06	0.04	0.06	0.03	0.05	0.05	0.05	--
1125	0.00	0.04	0.06	0.06	0.05	0.03	0.05	0.03	0.05	0.05	0.04	--
1175	0.00	0.03	0.04	0.06	0.05	0.03	0.05	0.03	0.05	0.05	0.04	--
1225	0.00	0.03	0.04	0.06	0.05	0.03	0.05	0.03	0.05	0.04	0.04	--
1275	0.00	0.03	0.03	0.06	0.05	0.03	0.05	0.03	0.04	0.04	0.04	--
1325	0.00	0.03	0.03	0.05	0.05	0.03	0.05	0.03	0.04	0.04	0.04	--
1375	0.00	0.03	0.05	0.05	0.05	0.03	0.05	0.03	0.05	0.06	0.05	--
1425	0.00	0.03	0.05	0.05	0.05	0.03	0.05	0.03	0.05	0.04	0.04	--
1475	0.00	0.03	0.03	0.05	0.05	0.03	0.05	0.03	0.05	0.05	0.05	--
1525	0.00	0.03	0.03	0.05	0.05	0.03	0.05	0.03	0.04	0.04	0.04	--
1575	0.00	0.03	0.03	0.05	0.05	0.03	0.05	0.03	0.04	0.04	0.04	--
1625	0.00	0.03	0.03	0.05	0.05	0.03	0.05	0.03	0.04	0.04	0.03	--
1675	0.00	0.03	0.04	0.05	0.05	0.03	0.05	0.03	0.05	0.05	0.05	--
1725	0.00	0.03	0.04	0.05	0.05	0.03	0.04	0.03	0.03	0.04	0.04	--
1775	0.00	0.03	0.03	0.05	0.05	0.03	0.04	0.03	0.04	0.04	0.04	--
1825	0.00	0.03	0.03	0.04	0.05	0.03	0.04	0.03	0.03	0.04	0.04	--
1875	0.00	0.03	0.03	0.05	0.05	0.03	0.04	0.03	0.03	0.03	0.03	--
1925	0.00	0.03	0.03	0.05	0.04	0.03	0.04	0.02	0.03	0.03	0.03	--
1975	0.00	0.03	0.03	0.05	0.05	0.03	0.05	0.02	0.03	0.03	0.03	--

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 8 von 199 Page 8 of 199
---	---------------------	----------------------------------

Higher frequency Harmonics												
P/P _n [%]	0	10	20	30	40	50	60	70	80	90	100	Limit
f [kHz]	I/In [%]											
2.1	0.01	0.23	0.15	0.20	0.14	0.17	0.18	0.21	0.20	0.19	0.23	--
2.3	0.01	0.14	0.15	0.13	0.13	0.11	0.14	0.16	0.13	0.12	0.14	--
2.5	0.01	0.11	0.17	0.12	0.15	0.11	0.14	0.18	0.16	0.13	0.11	--
2.7	0.01	0.24	0.19	0.13	0.13	0.18	0.14	0.20	0.25	0.26	0.24	--
2.9	0.01	0.20	0.08	0.12	0.11	0.14	0.10	0.15	0.21	0.21	0.20	--
3.1	0.01	0.26	0.09	0.11	0.13	0.08	0.11	0.15	0.31	0.29	0.26	--
3.3	0.01	0.27	0.10	0.10	0.11	0.06	0.11	0.15	0.27	0.25	0.27	--
3.5	0.00	0.16	0.07	0.08	0.08	0.07	0.09	0.08	0.07	0.08	0.16	--
3.7	0.00	0.06	0.11	0.06	0.07	0.09	0.08	0.07	0.07	0.06	0.06	--
3.9	0.01	0.07	0.11	0.09	0.09	0.09	0.09	0.08	0.07	0.07	0.07	--
4.1	0.00	0.05	0.09	0.07	0.08	0.06	0.08	0.07	0.07	0.06	0.05	--
4.3	0.00	0.06	0.10	0.06	0.06	0.10	0.05	0.10	0.08	0.07	0.06	--
4.5	0.00	0.07	0.08	0.06	0.06	0.10	0.05	0.07	0.07	0.07	0.07	--
4.7	0.00	0.08	0.08	0.13	0.12	0.08	0.12	0.09	0.08	0.08	0.08	--
4.9	0.00	0.05	0.04	0.09	0.09	0.04	0.10	0.04	0.04	0.04	0.05	--
5.1	0.00	0.04	0.03	0.06	0.06	0.03	0.06	0.03	0.04	0.04	0.04	--
5.3	0.00	0.04	0.04	0.06	0.06	0.04	0.05	0.04	0.04	0.04	0.04	--
5.5	0.00	0.03	0.02	0.05	0.06	0.02	0.05	0.02	0.03	0.03	0.03	--
5.7	0.00	0.02	0.02	0.05	0.05	0.02	0.04	0.02	0.02	0.02	0.02	--
5.9	0.00	0.02	0.02	0.04	0.04	0.02	0.04	0.02	0.02	0.02	0.02	--
6.1	0.00	0.02	0.02	0.04	0.03	0.02	0.03	0.02	0.02	0.02	0.02	--
6.3	0.00	0.01	0.01	0.03	0.03	0.01	0.03	0.01	0.01	0.01	0.01	--
6.5	0.00	0.01	0.01	0.02	0.02	0.01	0.02	0.01	0.01	0.01	0.01	--
6.7	0.00	0.01	0.01	0.02	0.02	0.01	0.02	0.01	0.01	0.01	0.01	--
6.9	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	--
7.1	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	--
7.3	0.00	0.01	0.00	0.01	0.01	0.00	0.01	0.00	0.01	0.01	0.01	--
7.5	0.00	0.01	0.00	0.01	0.01	0.00	0.01	0.00	0.00	0.00	0.01	--
7.7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	--
7.9	0.00	0.00	0.00	0.01	0.01	0.00	0.01	0.00	0.00	0.00	0.00	--
8.1	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	--
8.3	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	--
8.5	0.00	0.00	0.00	0.01	0.01	0.00	0.01	0.00	0.00	0.00	0.00	--
8.7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	--
8.9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	--

Note(s): The max. value of three phases were chosen.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 9 von 199 Page 9 of 199
---	---------------------	----------------------------------

5.2.5	TABLE: Commutation notches			P
Test Conditions P/ P _{E_{max}}	Measurements			
	I _{com} [A]			
	L1	L2	L3	
	25% - 35%	1.4	2.0	3.2
65% - 75%	1.9	3.1	3.3	
> 90%	2.2	3.2	3.7	
Note(s):				

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 10 von 199 Page 10 of 199
---	---------------------	------------------------------------

5.2.6	TABLE: DC current feeding to network (I _{dc})			P
Test Conditions P/ P _{E_{max}}	Measurements			Limit
	I _{dc} / I _n [%]			I _{dc} /I _n
	L1	L2	L3	
30% - 40%	0.09	0.33	0.29	0.5%
60% - 70%	0.34	0.24	0.30	0.5%
> 95%	0.08	0.16	0.20	0.5%
Note(s):				

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 11 von 199 Page 11 of 199
---	---------------------	------------------------------------

5.3.2		TABLE: Tests of three-phase inverter (Imbalance)					P
Test Conditions		Measurements					Limit
cosφ	S/S _{E_{max}} [%]	S _{asy} /S _{E_{max}} [%]					S _{asy} /S _{E_{max}} [%]
1.0	100	0.06	0.06	0.06	0.06	0.05	≤ ±5
1.0	50	0.08	0.08	0.09	0.09	0.08	
Max. un	100	0.05	0.05	0.05	0.05	0.05	
Max. un	50	0.05	0.05	0.05	0.05	0.05	
Max. ov	100	0.06	0.06	0.07	0.07	0.06	
Max. ov	50	0.07	0.07	0.07	0.07	0.07	
Note(s): S _{asy} : Max. Asymmetry power among three phases.							

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 12 von 199 Page 12 of 199
---	---------------------	------------------------------------

5.4.2		TABLE: Measurement of active- and reactive power ranges (P&Q range)				P		
Test Conditions		Measurements				Δ Limit		
U/Un	cosφ	U [V]	P _{max} [W]	cosφ	S _{max} [VA]	cosφ	P _{max} / P _{Emax}	S _{max} / S _{Emax}
0.9	1.0	207.3	8758.7	1.000	8759.0	--	≤102%	≤102%
1.0		230.3	8792.2	1.000	8792.7			
1.09		250.7	8790.0	0.999	8790.7			
0.9	Max.un	207.0	7889.8	0.901	8751.5	≤0.9		
1.0		230.1	7900.9	0.899	8784.1			
1.09		250.8	7903.4	0.900	8775.1			
0.9	Max.ov	207.2	7899.4	0.899	8782.7			
1.0		230.2	7906.6	0.899	8790.9			
1.09		250.8	7911.0	0.900	8785.1			
Note(s):								

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 13 von 199 Page 13 of 199
---	---------------------	------------------------------------

5.4.3(a)	TABLE: Active power reduction through setting provision (P control)			P
Test Conditions	Measurements			Limit
P/Pn [%]	P/P _{Emax} [%]	$\Delta P/P_{Emax}$ [%]		$\Delta P/Pn$ [%]
100	100.1	0.1		≤ 5%
90	90.1	0.1		
80	77.5	-2.6		
70	70.1	0.1		
60	60.0	0.0		
50	50.0	0.0		
40	39.7	-0.3		
30	29.8	-0.2		
20	19.9	-0.1		
10	10.0	0.0		
No disconnection occur				N

5.4.3(b)	TABLE: Active power reduction through setting provision (P control)		P
Test Conditions	Measurements		Limit
P/Pn [%]	$\Delta P/\Delta t$ [%Pn/s]		$\Delta P/\Delta t$ [%Pn/s]
100->5	0.49		0.33-0.66
5->100	0.49		

5.4.3(c)	TABLE: Active power reduction through setting provision (P control)			P
Test Conditions			Measurements	Limit
P/Pn [%]			P/Pn [%]	P/Pn [%]
Interface port 1	Interface port 2	Interface port 3		
70	90	50	49.5	≤ 50
Meter	N/A	Wifi		
P/Pn [%]				
Interface port 1	Interface port 2	Interface port 3	59.8	≤ 60
60	100	80		
Meter	Wifi	N/A		
P/Pn [%]			49.7	≤ 50
Interface port 1	Interface port 2	Interface port 3		
90	50	70		
Meter	Wifi	N/A		

5.4.3(d)	TABLE: Active power reduction through setting provision (P control)		P
Test Conditions		Measurements	Limit
P/Pn [%]		T _{response} [s]	T _{response} [s]
100->0		2.5	≤ 5

Note(s):

Prüfbericht-Nr.:
 Test report no.:


CN2283DK 003

 Seite 14 von 199
 Page 14 of 199

5.4.4(a)		TABLE: Active power output of PGU by over-frequency (LFSM-O)							P		
LFSM-O settings		f_{active}		f_{stop}			$f_{deactive}$		Droop		
		50.2		N/A			50.2		5%(40%P _M /Hz)		
Test Conditions		Measurements					Target	Tolerance	Limit		
f [Hz]	P _{rim} [%]	P/P _E max [%]	f [Hz]	T _{rise} [s]	T _{set} [s]	T _v [s]	P/P _E max [%]	ΔP/P _E max [%]	ΔP [%]	T _{rise} [s]	T _{set} [s]
50.00	100	99.9%	50.00	--	--	--	100	-0.1%	≤±10	≤2	≤20
50.25	100	98.3%	50.25	1.70	1.70	0.00	98	0.3%			
50.70	100	80.0%	50.70	1.80	1.80	0.00	80	0.0%			
51.40	100	51.8%	51.40	1.80	1.80	0.20	52	-0.2%			
50.70	100	80.0%	50.70	1.00	1.00	0.00	80	0.0%			
50.25	100	98.3%	50.25	1.50	1.50	0.00	98	0.3%			
50.00	100	99.9%	50.00	0.70	0.70	0.00	100	-0.1%			
51.65	100	Disconnection					0	--			
50.15	100	No Reconnection					0	--			
Test Conditions		Measurements					Target	Tolerance			
f [Hz]	P _{rim} [%]	P/P _E max [%]	f [Hz]	ΔP/Δt [%/min]		P/P _E max [%]	ΔP/P _E max [%]	ΔP [%]	ΔP/Δt [%/min]		
50.00	100	99.9%	50.00	9.07		100	-0.1%	≤±10	≤10		

Note(s):


Plotting diagram:



Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 15 von 199 Page 15 of 199
---	---------------------	------------------------------------

5.4.4(b)		TABLE: Active power output of PGU by over-frequency (LFSM-O)							P		
LFSM-O settings		f _{active}		f _{stop}			f _{deactive}		Droop		
		50.5		N/A			50.2		12%(16.67%P _M /Hz)		
Test Conditions		Measurements					Target	Tolerance	Limit		
f [Hz]	P _{rim} [%]	P/P _E max [%]	f [Hz]	T _{rise} [s]	T _{set} [s]	T _v [s]	P/P _E max [%]	ΔP/P _E max [%]	ΔP [%]	T _{rise} [s]	T _{set} [s]
50.00	60	60.0%	50.00	--	--	--	60	-0.02%	≤±10	≤2	≤20
50.40	60	60.0%	50.40	--	--	--	60	-0.03%			
50.70	60->100	57.9%	50.70	1.80	1.80	0.0	58	-0.06%			
51.40	100	50.9%	51.40	1.80	1.80	0.3	51	-0.06%			
50.70	100	58.0%	50.70	1.00	1.00	0.2	58	-0.05%			
50.40	100	60.0%	50.40	1.70	1.70	0.0	60	-0.01%			
Test Conditions		Measurements				Target	Tolerance	Limit			
f [Hz]	P _{rim} [%]	P/P _E max [%]	f [Hz]	ΔP/Δt [%/min]	P/P _E max [%]	ΔP/P _E max [%]	ΔP [%]	ΔP/Δt [%/min]			
50.00	100	100.0%	50.00	9.08	100	0.0%	≤±10	≤10			

Note(s):



Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 16 von 199
 Page 16 of 199

5.4.6(a)		TABLE: Active power output of PGU by under-frequency (LFSM-U)							P					
LFSM-U settings		f_{active}		f_{stop}			$f_{deactive}$		Droop					
		49.8		N/A			49.8		5%(40%P _{E_{max}} /Hz)					
Test Conditions		Measurements					Target	Tolerance	Limit					
f [Hz]	P _{rim} [%]	P/P _{E_{max}} [%]	f [Hz]	T _{rise} [s]	T _{set} [s]	T _v [s]	P/P _{E_{max}} [%]	$\Delta P/P_{E_{max}}$ [%]	ΔP [%]	T _{rise} [s]	T _{set} [s]			
50.00	100	10.0%	50.00	--	--	--	10	0.01%	$\leq \pm 10$	≤ 2	≤ 20			
49.75	100	12.4%	49.75	1.60	1.80	0.1	12	0.45%						
48.80	100	50.0%	48.80	1.50	1.50	0.1	50	0.02%						
47.60	100	98.1%	47.60	1.20	1.20	0.0	98	0.06%						
48.80	100	50.0%	48.80	1.70	1.70	0.0	50	-0.01%						
49.75	100	12.4%	49.75	1.90	1.90	0.2	12	0.37%						
50.00	100	10.0%	50.00	0.50	0.50	0.1	10	-0.02%						
47.35	100	Disconnection					0	--						
47.40	100	No Reconnection					0	--						
Test Conditions		Measurements				Target	Tolerance	Limit						
f [Hz]	P _{rim} [%]	P/P _{E_{max}} [%]	f [Hz]	$\Delta P/\Delta t$ [%/min]	P/P _{E_{max}} [%]	$\Delta P/P_{E_{max}}$ [%]	ΔP [%]	$\Delta P/\Delta t$ [%/min]						
50.00	100	9.9%	50.00	9.10	10	-0.1%	$\leq \pm 10$	≤ 10						

Note(s):

Product power was limited to 10% at the beginning of test by a lower priority command from user.

Plotting diagram:



Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 17 von 199
 Page 17 of 199

5.4.6(b)		TABLE: Active power output of PGU by under-frequency (LFSM-U)							P		
LFSM-U settings		f_{active}		f_{stop}			$f_{deactive}$		Droop		
		49.8		N/A			49.8		5%(40%P _{E_{max}} /Hz)		
Test Conditions		Measurements					Target	Tolerance	Limit		
f [Hz]	P _{rim} [%]	P/P _{E_{max}} [%]	f [Hz]	T _{rise} [s]	T _{set} [s]	T _v [s]	P/P _{E_{max}} [%]	Δ P/P _{E_{max}} [%]	Δ P [%]	T _{rise} [s]	T _{set} [s]
50.00	100	60.1%	50.00	--	--	--	60	0.07%	$\leq \pm 10$	≤ 2	≤ 20
49.75	100	62.4%	49.75	1.40	1.40	0.7	62	0.43%			
49.20	100	84.0%	49.20	1.70	1.70	0.0	84	0.02%			
48.80	100	99.8%	48.80	1.90	1.90	0.1	100	-0.21%			
49.20	100	84.0%	49.20	1.80	1.80	0.0	84	-0.01%			
49.85	100	60.1%	49.85	1.20	1.20	0.0	60	0.07%			
50.00	100	60.1%	50.00	--	--	--	60	0.07%			

Note(s):

Product power was limited to 60% at the beginning of test by a lower priority command from user.

Plotting diagram:




Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 18 von 199 Page 18 of 199
---	---------------------	------------------------------------

5.4.8.2		TABLE: Tests of reactive power / displacement factor setting accuracy (Fixed $\cos\phi$)							P	
Test Conditions			Measurements					Target	Tolerance	Limit
U/Un [%]	P/P _{E_{max}} [%]	$\cos\phi$	P [W]	Q [Var]	S [VA]	U [V]	$\cos\phi$	Q [Var]	$\Delta Q/P_{E_{max}}$ [%]	$\Delta Q/P_{E_{max}}$ [%]
90	50	0.90 under-excited	4398	-2127	4886	207	0.900	-2416	-0.28	$\leq \pm 4$
90	S _{E_{max}}		7127	-3414	7904	207	0.901	-4169	0.49	$\leq \pm 4$
100	50		4404	-2055	5569	230	0.899	-2424	-0.22	$\leq \pm 4$
100	S _{E_{max}}		7911	-3770	8782	230	0.900	-4341	0.61	$\leq \pm 4$
110	50		4407	-2126	4895	253	0.900	-2419	-0.20	$\leq \pm 4$
110	S _{E_{max}}		7911	-3816	8784	253	0.900	-4346	0.63	$\leq \pm 4$
90	50	0.95 under-excited	4396	-1436	4626	207	0.950	-1642	-0.44	$\leq \pm 4$
90	S _{E_{max}}		7537	-2456	7928	207	0.950	-2990	0.39	$\leq \pm 4$
100	50		4585	-1433	4616	230	0.949	-1647	0.00	$\leq \pm 4$
100	S _{E_{max}}		8359	-2726	8795	231	0.950	-3127	0.48	$\leq \pm 4$
110	50		4404	-1444	4639	253	0.949	-1643	-0.35	$\leq \pm 4$
110	S _{E_{max}}		8343	-2730	8781	253	0.950	-3130	0.50	$\leq \pm 4$
90	50	0.90 over-excited	4404	2120	4890	207	0.900	2422	0.16	$\leq \pm 4$
90	S _{E_{max}}		7128	3452	7922	207	0.899	4161	-0.16	$\leq \pm 4$
100	50		4404	2063	5569	230	0.900	2429	-0.17	$\leq \pm 4$
100	S _{E_{max}}		7904	3817	8779	230	0.900	4348	-0.67	$\leq \pm 4$
110	50		4399	2126	4887	253	0.900	2424	-0.15	$\leq \pm 4$
110	S _{E_{max}}		7912	3818	8787	253	0.900	4379	-0.64	$\leq \pm 4$
90	50	0.95 over-excited	4404	1440	4636	207	0.950	1645	-0.22	$\leq \pm 4$
90	S _{E_{max}}		7521	2466	7919	207	0.950	2983	-0.27	$\leq \pm 4$
100	50		4399	1438	4630	230	0.950	1651	-0.17	$\leq \pm 4$
100	S _{E_{max}}		8348	2728	8784	230	0.950	3115	-0.20	$\leq \pm 4$
110	50		4408	1444	4641	253	0.949	1647	-0.14	$\leq \pm 4$
110	S _{E_{max}}		8307	2714	8741	253	0.950	3130	0.56	$\leq \pm 4$

Note(s):

P-Q Diagram:





Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 19 von 199
 Page 19 of 199

5.4.8.3(a)	TABLE: Tests of displacement factor- / active power character curve (cosφ(P))			P
cosφ (P) curve settings:	P/P _E max [%]	10	50	100
	cosφ	1.0	1.0	0.9
	3Tau [s]	10		
Test Conditions				Limit
P _{dc} /P _{dc,r} [%]				ΔQ/P _E max [%]
100->10->100 with ramp ≤30%P _{dc,r} /min				≤±4.0

Plotting diagram:





Prüfbericht-Nr.:
 Test report no.:


CN2283DK 003

 Seite 20 von 199
 Page 20 of 199

5.4.8.3(b)	TABLE: Tests of displacement factor- / active power character curve (cosφ(P))	P
Test Conditions	Measurements	Limit
$P_{rim}/P_{dc,r}$ [%]	Response time T [s]	Response time T [s]
100->40	9.5	Complied with PT-1 curve
40->100	9.5	
100->75	9.6	

Plotting diagram:

 $Q(t)$, $P_{Primary}$ Setting: $100\%P_{dc,r} \rightarrow 40\%P_{dc,r}$

 $Q(t)$, $P_{Primary}$ Setting: $40\%P_{dc,r} \rightarrow 100\%P_{dc,r}$




Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 22 von 199 Page 22 of 199
---	---------------------	------------------------------------


5.4.8.4(a)	TABLE: Tests of reactive power-voltage character curve (Q(U))					P
Q (U) curve settings:	U/Un	0.93	0.97	1.03	1.07	
	Q/S _{E_{max}}	+0.436	0	0	-0.436	
	3Tau [s]	6				
Test Conditions		Measurements		Target	Tolerance	Limit
U/Un[%]		Q[Var]	U [V]	Q[Var]	ΔQ/P _{E_{max}} [%]	ΔQ/P _{E_{max}} [%]
100	-63.6	230.1	0	-0.72	≤±4	
99	-66.2	227.5	0	-0.75	≤±4	
98	-68.3	225.2	0	-0.78	≤±4	
97	-70.3	223.2	0	-0.80	≤±4	
96	948.6	220.9	959	-0.12	≤±4	
95	1905.2	218.7	1918	-0.15	≤±4	
94	2849.6	216.4	2878	-0.32	≤±4	
93	3802.0	213.5	3837	-0.40	≤±4	
92	3808.3	211.9	3837	-0.33	≤±4	
91	3846.7	209.6	3837	0.11	≤±4	
90	3836.1	207.2	3837	-0.01	≤±4	
91	3838.1	209.6	3837	0.01	≤±4	
92	3840.9	211.9	3837	0.04	≤±4	
93	3842.6	213.5	3837	0.06	≤±4	
94	2854.9	216.5	2878	-0.26	≤±4	
95	1907.3	218.7	1918	-0.12	≤±4	
96	949.5	221.0	959	-0.11	≤±4	
97	-70.8	223.3	0	-0.80	≤±4	
98	-68.5	225.5	0	-0.78	≤±4	
99	-66.2	227.8	0	-0.75	≤±4	
100	-63.7	230.3	0	-0.72	≤±4	
101	-61.8	232.3	0	-0.70	≤±4	
102	-58.0	234.6	0	-0.66	≤±4	
103	-57.5	236.9	0	-0.65	≤±4	
104	-936.0	239.1	-959	0.26	≤±4	
105	-1898.7	241.4	-1918	0.22	≤±4	
106	-2856.8	243.6	-2878	0.24	≤±4	
107	-3814.6	245.9	-3837	0.25	≤±4	
108	-3812.3	248.2	-3837	0.28	≤±4	
109	-3807.9	250.5	-3837	0.33	≤±4	
110	-3806.9	253.0	-3837	0.34	≤±4	
109	-3806.9	250.7	-3837	0.34	≤±4	
108	-3812.9	248.2	-3837	0.27	≤±4	
107	-3815.8	245.9	-3837	0.24	≤±4	
106	-2857.3	243.7	-2878	0.24	≤±4	
105	-1901.2	241.4	-1918	0.19	≤±4	
104	-936.0	239.1	-959	0.26	≤±4	
103	-57.4	236.9	0	-0.65	≤±4	
102	-59.9	234.6	0	-0.68	≤±4	
101	-61.7	232.3	0	-0.70	≤±4	
100	-61.6	230.3	0	-0.70	≤±4	

Prüfbericht-Nr.:
 Test report no.:



CN2283DK 003


Seite 23 von 199
 Page 23 of 199

Diagram:



5.4.8.4(b)	TABLE: Tests of reactive power-voltage character curve (Q(U))					P
Test Conditions	Measurement			Target	Limit	
	Settling time T [s]	Q _{Start} [Var]	Q _{end} [Var]	Q _{end} /S _{E_{max}} [%]	Settling time T [s]	$\Delta Q_{end}/P_{E_{max}}$ [%]
Un -> Un+ $\Delta U_{ind,Y}$	5.5	-139	-3268	0.37	Refer to PT-1 curve	--
Un+ $\Delta U_{ind,Y}$ -> Un	5.7	-3271	-77	0		$\leq \pm 4$
Un -> Un+ $\Delta U_{ind,Y}$	5.6	-124	-3268	0.37		--
Un+ $\Delta U_{ind,Y}$ -> Un	5.6	-3760	-85	0		$\leq \pm 4$
Un -> Un+ $\Delta U_{ind,Y}$	5.4	-130	-3262	0.37		--
Un+ $\Delta U_{ind,Y}$ -> Un	5.6	-3770	-88	0		$\leq \pm 4$
Un -> Un+ $\Delta U_{cap,Y}$	5.3	45	3272	0.37		--
Un+ $\Delta U_{cap,Y}$ -> Un	5.3	3220	-55	0		$\leq \pm 4$
Un -> Un+ $\Delta U_{cap,Y}$	5.8	37	3277	0.37		--
Un+ $\Delta U_{cap,Y}$ -> Un	5.6	3269	-14	0		$\leq \pm 4$
Un -> Un+ $\Delta U_{cap,Y}$	5.5	40	3275	0.37		--
Un+ $\Delta U_{cap,Y}$ -> Un	5.5	3275	30	0		$\leq \pm 4$

 Plotting Diagram
 Un -> Un+ $\Delta U_{ind,Y}$

 Un+ $\Delta U_{ind,Y}$ -> Un




Note(s): Xnet=1.06Ohm

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 26 von 199
 Page 26 of 199

5.5.2, 5.5.4, 5.5.6		TABLE: NS-protection, Integrated interface switch (Functional safety)					P
No.	component No.	fault	test voltage (V)	test time	fuse No.	fuse current (A)	result
1.	PCE input	Reversed	DC 480/85 0	30min			DC Input: 0Vdc / 0A / 0W AC Output: 0Vac / 0A / 0kW FID: The inverter does not work. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
2.	PCE input	s-c	DC 480/85 0	30min			DC Input: 0Vdc / 0A / 0W AC Output: 0Vac / 0A / 0kW FID: The inverter does not work. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
3.	PCE input	Over-voltage	DC 480/85 0	30min			DC Input: 1050Vdc / 0A / 0W AC Output: 0Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F55' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 27 von 199 Page 27 of 199
---	---------------------	------------------------------------

4.	PCE input (only for multi-string)	Different input MPP1: low input MPP2: high input	DC 480/850	30min			DC Input: mpp1: 480Vdc / 10.42A / 5kW mpp2: 850Vdc / 5.88A / 5kW AC Output: 230Vac / 14.06A / 9.7kW FID: The inverter works normally. MT: n.a. SD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, GD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
5.	PCE input (only for multi-string)	Same input (MPP1 & MPP2 from same power source)	DC 480/850	30min			DC Input:mpp1: 850Vdc / 5.88A / 5kW mpp2: 850Vdc /5.88A / 5kW AC Output: 230Vac / 14.06A / 9.7kW FID: The inverter works normally. MT: n.a. SD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, GD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
6.	PCE output	Power over-feed (OCP & OTP function controlled by DSP / software is disable)	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F18' was faulty. MT: SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 28 von 199
 Page 28 of 199

7.	PCE output	Over-voltage (OVP function controlled by DSP / software is disable)	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 300Vac / 0A / 0kW FID: When output phase voltage rised from 230V to 300V,The inverter stopped working immediately, and the LCD showed that 'F26' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
8.	PCE output (A to B)	s-c	DC 480/850	30min		DC Input:850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F18' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
9.	PCE output (A to C)	s-c	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F18' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 29 von 199
 Page 29 of 199

10.	PCE output (B to C)	s-c	DC 480/85 0	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F18' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
11.	PCE output	Phase sequence or polarity incorrect	DC 480/85 0	30min		DC Input: 850Vdc / 11.76A / 10kW AC Output: 230Vac / 14.06A / 9.7kW FID: The inverter works normally. MT: n.a. SD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, GD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
12.	PCE output	A-Phase mis- wiring grid connectio n	DC 480/85 0	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F42' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 30 von 199
 Page 30 of 199

13.	PCE output	B-Phase mis-wiring grid connection	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F42' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
14.	PCE output	C-Phase mis-wiring grid connection	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F42' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
15.	PCE Cooling system failure	Fan locked (MF1)	DC 480/850	30min		DC Input: 480Vdc / 10.83A / 5.2kW AC Output: 207Vac / 7.27A / 5kW FID: The inverter works normally. MT: Ambient=65°C, enclosure=68.61°C SD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, GD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 31 von 199 Page 31 of 199
---	---------------------	------------------------------------

16.	PCE Cooling system failure	opening blocked	DC 480/85 0	30min		DC Input: 480Vdc / 10.83A / 5.2kW AC Output: 207Vac / 7.27A / 5kW FID: The inverter works normally. MT: n/a SD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, GD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
17.	PCE output overload	o-l	DC 480/85 0	30min		DC Input: 480Vdc / 10.83A / 5.2kW AC Output: 207Vac / 7.27A / 5kW FID: The inverter works normally. MT: Ambient=65°C, enclosure=68.36°C SD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, GD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
18.	PCE Cooling system failure	blanket test	DC 480/85 0	30min		DC Input: 480Vdc / 10.83A / 5.2kW AC Output: 207Vac / 7.27A / 5kW FID: The inverter works normally. MT: Ambient=65°C, enclosure=68.8°C SD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, GD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

MCU or DPS processer failure

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 32 von 199 Page 32 of 199
---	---------------------	------------------------------------

19.	DSP failure	+1.8V power supply disable	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'comm error' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
20.	DSP failure	+3.3V power supply disable	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'comm error' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
21.	DSP failure	+5V power supply disable	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'comm error' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
Loss of control & Function check fault							

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 33 von 199
 Page 33 of 199

22.	IGBT PMW	Loss / failure (no power)	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F26' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
23.	IGBT PMW	Loss / failure (one bridge on always)	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, the IGBT QR2 damaged, and the LCD showed that 'F26' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
24.	IGBT PMW	Loss / failure (No driver)	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F26' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 34 von 199 Page 34 of 199
---	---------------------	------------------------------------

25.	PV/DC Voltage detector C30 S-C	Loss / failure	DC 480/850	30min			DC Input: 0Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, the LCD showed that 'F41' was faulty, and the DC indicator on the LCD is off . MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
26.	PV/DC current detector R110 O-C	Loss / failure	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, the LCD showed that 'F41' was faulty, and the DC indicator on the LCD is off . MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
27.	BUS Voltage detector C24 S-C	Loss / failure	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F56' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 35 von 199
 Page 35 of 199

28.	Inverter current detector U3 3 to 4 S-C	Loss / failure	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F26' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
29.	Inverter voltage detector R127 S-C	Loss / failure	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 260Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F41' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
30.	Grid/AC voltage detector R331 S-C	Loss / failure	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 260Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F41' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 36 von 199 Page 36 of 199
---	---------------------	------------------------------------

31.	PV isolation device function check R39 S-C	Loss / failure	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 260Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F24' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
32.	Relay / Contactor function check (RY1 o-c)	Loss / failure	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F30' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
33.	Relay / Contactor function check (RY3 o-c)	Loss / failure	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F30' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 37 von 199
 Page 37 of 199

34.	Relay / Contactor function check (RY5 o-c)	Loss / failure	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F30' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
35.	RCD/RC M function check	Loss / failure	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F23' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
36.	Heat-sink temperat ure detector C38S-C	Loss / failure (s-c)	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F64' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 38 von 199 Page 38 of 199
---	---------------------	------------------------------------

37.	Heat-sink temperature detector R510-C	Loss / failure(o-c)	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F64' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
Components single fault condition and Functional insulation on PWB short circuit test							
38.	IGBT (IGBT D-S) Q8 D-S S-C	s-c	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the IGBT Q8,Q9 are damaged. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, NCD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
39.	DC input Bus capacitor (820µF) C141 S-C	s-c	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the Bus capacitor C142,C30,C39,C50 are damaged. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, NCD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 39 von 199
 Page 39 of 199

40.	DC input filter capacitor C153 S-C	s-c	DC 480/850	30min		DC Input: 0Vdc / 0A / 0W AC Output: 0Vac / 0A / 0kW FID: The inverter does not work. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
41.	LC filter capacitor C28 S-C	s-c	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F18' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
42.	Power supply transformer (T1) 1 to 3 S-C	s-c	DC 480/850	30min		DC Input: 0Vdc / 0A / 0W AC Output: 0Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD turns off. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
43.	Power supply transformer (T1) 4 to 5 S-C	s-c	DC 480/850	30min		DC Input: 0Vdc / 0A / 0W AC Output: 0Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD turns off. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 40 von 199
 Page 40 of 199

44.	Power supply transformer (T1) 6 to 7 S-C	s-c	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F41' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
45.	Power supply transformer (T1) 9 to 10 S-C	s-c	DC 480/850	30min		DC Input: 850Vdc / 11.76A / 10kW AC Output: 230Vac / 14.06A / 9.7kW FID: The inverter works properly, but wifi does not work properly. MT: n.a. SD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No, GD: <input type="checkbox"/> Yes / <input checked="" type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
46.	Power supply transformer (T1) 12 to 13 S-C	s-c	DC 480/850	30min		DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F41' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 41 von 199 Page 41 of 199
---	---------------------	------------------------------------

47.	Power supply transformer (T1) 14 to 15 S-C	s-c	DC 480/850	30min			DC Input: 850Vdc / 0A / 0W AC Output: 230Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD showed that 'F23' was faulty. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.
48.	Power supply transformer (T1) 15 to 16 S-C	s-c	DC 480/850	30min			DC Input: 0Vdc / 0A / 0W AC Output: 0Vac / 0A / 0kW FID: The inverter stopped working immediately, and the LCD turns off. MT: n.a. SD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, GD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No RO: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No, NCD: <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No NH: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail. DST: <input checked="" type="checkbox"/> Pass / <input type="checkbox"/> Fail.

Legend (Special evaluation for PV Inverter abnormal test)

FID	Fault Indication	MT	Max. Temperature
SD	PCE Shut Down:	DG	Disconnection To Grid
RO	Recovered to Operate after removing the single fault setting	NCD	No comp. or parts damaged
NH	No hazards occurred	DST	Dielectric strength test
s-c	short-circuited	o-c	open-circuited
o-l	Over-load.		

Note(s):

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 42 von 199 Page 42 of 199
---	---------------------	------------------------------------

5.5.7(a)	TABLE: Protection devices and protection settings (OV/UV)					P
Condition	Setting U/Un [%]	Measurement				Limitation $\Delta U/U_n$ [%]
		Trip value [V]				
		L123	L1	L2	L3	
U>>	125	288.1	288.6	288.5	288.8	$\leq \pm 1.0$
U<	80	183.6	183.1	182.8	183.3	
U<<	45	103.2	103.1	102.8	102.7	
Condition	Setting U/Un [%]	Measurement				Limitation $\Delta U/U_n$ [%]
		Trip value [V]				
		L123	L1-L2	L2-L3	L3-L1	
U>>	125	--	--	--	--	$\leq \pm 1.0$
U<	80	--	--	--	--	
U<<	45	--	--	--	--	
Condition	Setting [ms]	Measurement				Limitation [ms]
		Trip time [ms]				
		L123	L1	L2	L3	
U>>	100	112	123	126	130	≤ 200
U<	3000	3035	3038	3032	3046	3000-3100
U<<	300	353	348	352	314	300-400
Condition	Setting	Measurement				Limitation [ms]
		Trip time [ms]				
		L123	L1-L2	L2-L3	L3-L1	
U>>	100	--	--	--	--	≤ 200
U<	3000	--	--	--	--	3000-3100
U<<	300	--	--	--	--	300-400
Condition	Setting [s]	Measurement				Limitation [s]
		Trip time [s]				
		L123	L1	L2	L3	
U> 230->257.6	500	500.0	--	--	--	450-550
U> 230->248.4	No disconnect	No disconnect	--	--	--	No disconnect
U> 244->262.2	300	--	305.0	--	--	225-375

Note(s):
Tests on L-L voltages are applicable to product over 30kVA.

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 43 von 199 Page 43 of 199
---	---------------------	------------------------------------

5.5.7(b)	TABLE: Protection devices and protection settings (OF/UF)		P
Condition	Setting f [Hz]	Measurement	Limitation $\Delta f/f_n$ [%]
		Trip value [Hz]	
f>	51.5	51.5	$\leq \pm 0.1$
f<	47.5	47.5	
Condition	Setting [ms]	Measurement	Limitation [ms]
		Trip time [ms]	
f>	100	110	≤ 200
f<	100	98	≤ 200
Note(s):			

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 44 von 199 Page 44 of 199
---	---------------------	------------------------------------

5.5.7(c)	TABLE: Protection devices and protection settings	P
1.	The last 5 fault indication can be read	Pass
	Fault 1:	Code"F48",AC lower frequency
	Fault 2:	Code"F55",DC busbar voltage is too high
	Fault 3:	Code"F45",AC Line U,V over voltage
	Fault 4:	Code"F45",AC Line U,V over voltage
	Fault 5:	Code"F35",No AC grid
2.	Fault indication can be read after a supply interruption $\leq 3s$	Pass
	Fault 1:	Code"F35",No AC grid
	Fault 2:	Code"F35",No AC grid
	Fault 3:	Code"F55",DC busbar voltage is too high
	Fault 4:	Code"F55",DC busbar voltage is too high
	Fault 5:	Code"F55",DC busbar voltage is too high

5.5.9	TABLE: Constructional features of NS protection	P
1.	The protection settings can be read on PGU or data interface equipment	Pass
		Interface equipment:
2.	The NS protection settings shall be protected.	Pass
		Protection type:
3.	If all protection settings are fixed	Pass

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 45 von 199 Page 45 of 199
---	---------------------	------------------------------------

5.5.10	TABLE: Islanding detection (per IEC 62116: 2014)					P
Power 100%						
Conditions	P _R [kW]	Q _L [kVar]	Q _C [kVar]	Q _f	Trip time [ms]	Limitation [ms]
P _R : -10% Q _C : +10%	L1: 2.40	L1: 3.11	L1: 2.94	1.061	257.8	9000
	L2: 2.39	L2: 3.07	L2: 2.94	1.095		
	L3: 2.40	L3: 3.03	L3: 2.94	1.097		
P _R : -10% Q _C : +5%	L1: 2.40	L1: 3.11	L1: 2.80	1.046	277.1	9000
	L2: 2.39	L2: 3.07	L2: 2.80	1.079		
	L3: 2.40	L3: 3.03	L3: 2.80	1.082		
P _R : -10% Q _C : 0%	L1: 2.40	L1: 3.11	L1: 2.67	1.031	267.2	9000
	L2: 2.39	L2: 3.07	L2: 2.67	1.064		
	L3: 2.40	L3: 3.03	L3: 2.67	1.066		
P _R : -10% Q _C : -5%	L1: 2.40	L1: 3.11	L1: 2.54	1.015	259.5	9000
	L2: 2.39	L2: 3.07	L2: 2.54	1.045		
	L3: 2.40	L3: 3.03	L3: 2.54	1.046		
P _R : -10% Q _C : -10%	L1: 2.40	L1: 3.11	L1: 2.40	1.000	163.9	9000
	L2: 2.39	L2: 3.07	L2: 2.40	1.032		
	L3: 2.40	L3: 3.03	L3: 2.40	1.033		
P _R : -5% Q _C : +10%	L1: 2.54	L1: 3.11	L1: 2.94	1.061	429.2	9000
	L2: 2.53	L2: 3.07	L2: 2.94	1.061		
	L3: 2.54	L3: 3.03	L3: 2.94	1.063		
P _R : -5% Q _C : -10%	L1: 2.54	L1: 3.11	L1: 2.40	1.000	170.5	9000
	L2: 2.53	L2: 3.07	L2: 2.40	1.001		
	L3: 2.54	L3: 3.03	L3: 2.40	1.001		
P _R : 0% Q _C : +10%	L1: 2.67	L1: 3.11	L1: 2.94	1.029	476.3	9000
	L2: 2.66	L2: 3.07	L2: 2.94	1.030		
	L3: 2.67	L3: 3.03	L3: 2.94	1.031		
P _R : -5% Q _C : +5%	L1: 2.54	L1: 3.11	L1: 2.80	1.046	479.8	9000
	L2: 2.53	L2: 3.07	L2: 2.80	1.047		
	L3: 2.54	L3: 3.03	L3: 2.80	1.048		
P _R : -5% Q _C : 0%	L1: 2.54	L1: 3.11	L1: 2.67	1.031	530.5	9000
	L2: 2.53	L2: 3.07	L2: 2.67	1.032		
	L3: 2.54	L3: 3.03	L3: 2.67	1.033		
P _R : -5% Q _C : -5%	L1: 2.54	L1: 3.11	L1: 2.54	1.015	173.5	9000
	L2: 2.53	L2: 3.07	L2: 2.54	1.017		
	L3: 2.54	L3: 3.03	L3: 2.54	1.017		
P _R : 0% Q _C : +5%	L1: 2.67	L1: 3.11	L1: 2.80	1.015	1043.0	9000
	L2: 2.66	L2: 3.07	L2: 2.80	1.016		

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 46 von 199 Page 46 of 199
---	---------------------	------------------------------------

	L3: 2.67	L3: 3.03	L3: 2.80	1.016		
P _R : 0% Q _C : 0%	L1: 2.67	L1: 3.11	L1: 2.67	0.999	842.0	9000
	L2: 2.66	L2: 3.07	L2: 2.67	1.001		
	L3: 2.67	L3: 3.03	L3: 2.67	1.001		
P _R : 0% Q _C : -5%	L1: 2.67	L1: 3.11	L1: 2.54	0.985	494.6	9000
	L2: 2.66	L2: 3.07	L2: 2.54	0.987		
	L3: 2.67	L3: 3.03	L3: 2.54	0.986		
P _R : +5% Q _C : +5%	L1: 2.80	L1: 3.11	L1: 2.80	0.985	415.1	9000
	L2: 2.79	L2: 3.07	L2: 2.80	0.987		
	L3: 2.80	L3: 3.03	L3: 2.80	0.987		
P _R : +5% Q _C : 0%	L1: 2.80	L1: 3.11	L1: 2.67	0.971	808.9	9000
	L2: 2.79	L2: 3.07	L2: 2.67	0.973		
	L3: 2.80	L3: 3.03	L3: 2.67	0.972		
P _R : +5% Q _C : -5%	L1: 2.80	L1: 3.11	L1: 2.54	0.957	418.0	9000
	L2: 2.79	L2: 3.07	L2: 2.54	0.959		
	L3: 2.80	L3: 3.03	L3: 2.54	0.958		
P _R : 0% Q _C : -10%	L1: 2.67	L1: 3.11	L1: 2.40	0.970	154.7	9000
	L2: 2.66	L2: 3.07	L2: 2.40	0.972		
	L3: 2.67	L3: 3.03	L3: 2.40	0.971		
P _R : +5% Q _C : +10%	L1: 2.80	L1: 3.11	L1: 2.94	0.999	633.5	9000
	L2: 2.79	L2: 3.07	L2: 2.94	1.001		
	L3: 2.80	L3: 3.03	L3: 2.94	1.001		
P _R : +5% Q _C : -10%	L1: 2.80	L1: 3.11	L1: 2.40	1.000	158.5	9000
	L2: 2.79	L2: 3.07	L2: 2.40	1.001		
	L3: 2.80	L3: 3.03	L3: 2.40	1.001		
P _R : +10% Q _C : +10%	L1: 2.94	L1: 3.11	L1: 2.94	0.971	556.4	9000
	L2: 2.93	L2: 3.07	L2: 2.94	0.973		
	L3: 2.94	L3: 3.03	L3: 2.94	0.973		
P _R : +10% Q _C : +5%	L1: 2.94	L1: 3.11	L1: 2.80	0.958	818.5	9000
	L2: 2.93	L2: 3.07	L2: 2.80	0.960		
	L3: 2.94	L3: 3.03	L3: 2.80	0.959		
P _R : +10% Q _C : 0%	L1: 2.94	L1: 3.11	L1: 2.67	0.952	574.0	9000
	L2: 2.93	L2: 3.07	L2: 2.67	0.954		
	L3: 2.94	L3: 3.03	L3: 2.67	0.953		
P _R : +10% Q _C : -5%	L1: 2.94	L1: 3.11	L1: 2.54	0.958	701.9	9000
	L2: 2.93	L2: 3.07	L2: 2.54	0.960		
	L3: 2.94	L3: 3.03	L3: 2.54	0.959		
P _R : +10% Q _C : -10%	L1: 2.94	L1: 3.11	L1: 2.40	0.972	179.2	9000
	L2: 2.93	L2: 3.07	L2: 2.40	0.973		

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 47 von 199 Page 47 of 199
---	---------------------	------------------------------------

	L3: 2.94	L3: 3.03	L3: 2.40	0.973		
Power 66%						
Conditions	P _R [kW]	Q _L [kVar]	Q _C [kVar]	Q _f	Trip time [ms]	Limitation [ms]
P _R : 0% Q _C : -5%	L1: 1.76	L1: 2.07	L1: 1.68	0.963	175.9	9000
	L2: 1.76	L2: 2.04	L2: 1.67	0.964		
	L3: 1.76	L3: 2.09	L3: 1.67	0.963		
P _R : 0% Q _C : -4%	L1: 1.76	L1: 2.07	L1: 1.70	0.970	276.0	9000
	L2: 1.76	L2: 2.04	L2: 1.69	0.972		
	L3: 1.76	L3: 2.09	L3: 1.69	0.970		
P _R : 0% Q _C : -3%	L1: 1.76	L1: 2.07	L1: 1.72	0.978	300.8	9000
	L2: 1.76	L2: 2.04	L2: 1.71	0.980		
	L3: 1.76	L3: 2.09	L3: 1.71	0.978		
P _R : 0% Q _C : -2%	L1: 1.76	L1: 2.07	L1: 1.73	0.985	461.5	9000
	L2: 1.76	L2: 2.04	L2: 1.72	0.987		
	L3: 1.76	L3: 2.09	L3: 1.72	0.985		
P _R : 0% Q _C : -1%	L1: 1.76	L1: 2.07	L1: 1.75	0.993	579.3	9000
	L2: 1.76	L2: 2.04	L2: 1.74	0.995		
	L3: 1.76	L3: 2.09	L3: 1.74	0.993		
P _R : 0% Q _C : 0%	L1: 1.76	L1: 2.07	L1: 1.77	1.000	780.0	9000
	L2: 1.76	L2: 2.04	L2: 1.76	1.002		
	L3: 1.76	L3: 2.09	L3: 1.76	1.000		
P _R : 0% Q _C : +1%	L1: 1.76	L1: 2.07	L1: 1.79	1.007	682.8	9000
	L2: 1.76	L2: 2.04	L2: 1.78	1.010		
	L3: 1.76	L3: 2.09	L3: 1.78	1.007		
P _R : 0% Q _C : +2%	L1: 1.76	L1: 2.07	L1: 1.81	1.014	515.1	9000
	L2: 1.76	L2: 2.04	L2: 1.80	1.017		
	L3: 1.76	L3: 2.09	L3: 1.80	1.015		
P _R : 0% Q _C : +3%	L1: 1.76	L1: 2.07	L1: 1.82	1.022	392.7	9000
	L2: 1.76	L2: 2.04	L2: 1.81	1.024		
	L3: 1.76	L3: 2.09	L3: 1.81	1.022		
P _R : 0% Q _C : +4%	L1: 1.76	L1: 2.07	L1: 1.84	1.029	288.6	9000
	L2: 1.76	L2: 2.04	L2: 1.83	1.032		
	L3: 1.76	L3: 2.09	L3: 1.83	1.029		
P _R : 0% Q _C : +5%	L1: 1.76	L1: 2.07	L1: 1.86	1.036	176.6	9000
	L2: 1.76	L2: 2.04	L2: 1.85	1.039		
	L3: 1.76	L3: 2.09	L3: 1.85	1.036		
Power 33%						


Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 48 von 199 Page 48 of 199
---	---------------------	------------------------------------

Conditions	P _R [kW]	Q _L [kVar]	Q _C [kVar]	Q _f	Trip time [ms]	Limitation [ms]
P _R : 0% Q _C : -5%	L1: 0.88	L1: 0.99	L1: 0.84	0.976	177.7	9000
	L2: 0.88	L2: 0.99	L2: 0.84	0.979		
	L3: 0.88	L3: 1.00	L3: 0.84	0.976		
P _R : 0% Q _C : -4%	L1: 0.88	L1: 0.99	L1: 0.84	0.981	353.1	9000
	L2: 0.88	L2: 0.99	L2: 0.84	0.984		
	L3: 0.88	L3: 1.00	L3: 0.84	0.981		
P _R : 0% Q _C : -3%	L1: 0.88	L1: 0.99	L1: 0.85	0.986	516.3	9000
	L2: 0.88	L2: 0.99	L2: 0.85	0.989		
	L3: 0.88	L3: 1.00	L3: 0.85	0.986		
P _R : 0% Q _C : -2%	L1: 0.88	L1: 0.99	L1: 0.86	0.990	579.7	9000
	L2: 0.88	L2: 0.99	L2: 0.86	0.994		
	L3: 0.88	L3: 1.00	L3: 0.86	0.990		
P _R : 0% Q _C : -1%	L1: 0.88	L1: 0.99	L1: 0.87	0.995	693.9	9000
	L2: 0.88	L2: 0.99	L2: 0.87	0.999		
	L3: 0.88	L3: 1.00	L3: 0.87	0.995		
P _R : 0% Q _C : 0%	L1: 0.88	L1: 0.99	L1: 0.88	1.000	891.3	9000
	L2: 0.88	L2: 0.99	L2: 0.88	1.004		
	L3: 0.88	L3: 1.00	L3: 0.88	1.000		
P _R : 0% Q _C : +1%	L1: 0.88	L1: 0.99	L1: 0.89	1.005	790.4	9000
	L2: 0.88	L2: 0.99	L2: 0.89	1.009		
	L3: 0.88	L3: 1.00	L3: 0.89	1.005		
P _R : 0% Q _C : +2%	L1: 0.88	L1: 0.99	L1: 0.90	1.009	528.0	9000
	L2: 0.88	L2: 0.99	L2: 0.90	1.014		
	L3: 0.88	L3: 1.00	L3: 0.90	1.009		
P _R : 0% Q _C : +3%	L1: 0.88	L1: 0.99	L1: 0.91	1.014	485.1	9000
	L2: 0.88	L2: 0.99	L2: 0.91	1.019		
	L3: 0.88	L3: 1.00	L3: 0.91	1.014		
P _R : 0% Q _C : +4%	L1: 0.88	L1: 0.99	L1: 0.92	1.019	324.3	9000
	L2: 0.88	L2: 0.99	L2: 0.92	1.024		
	L3: 0.88	L3: 1.00	L3: 0.92	1.019		
P _R : 0% Q _C : +5%	L1: 0.88	L1: 0.99	L1: 0.92	1.023	168.3	9000
	L2: 0.88	L2: 0.99	L2: 0.92	1.029		
	L3: 0.88	L3: 1.00	L3: 0.92	1.024		

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 49 von 199 Page 49 of 199
---	---------------------	------------------------------------

5.6	TABLE: Connection conditions and synchronization (Reconnection)			P
Condition	Measurement		Limitation	
	Reconnection	Delay time [s]	Reconnection	Delay time [s]
$f < 47.45\text{Hz}$	No	--	No	≥ 60
$f \geq 47.55\text{Hz}$	Yes	112	Yes	≥ 60
$f > 50.15\text{Hz}$	No	--	No	≥ 60
$f \leq 50.05\text{Hz}$	Yes	111	Yes	≥ 60
$U < 0.84U_n$	No	--	No	≥ 60
$U \geq 0.86U_n$	Yes	118	Yes	≥ 60
$U > 1.11U_n$	No	--	No	≥ 60
$U \leq 1.09U_n$	Yes	115	Yes	≥ 60


Note(s):

5.7	TABLE: $P_{AV,E}$ monitoring		P
$P_{AV,E}$ value setting: 60% P_n			
Power limit method			
Test method	Condition		
Cut of load	$P_{load}/P_n: 40\% \rightarrow 0\%$		
Power curve:			
			

Prüfbericht-Nr.: <i>Test report no.:</i>	CN2283DK 003	Seite 50 von 199 <i>Page 50 of 199</i>
--	---------------------	---


5.8	TABLE: Verification of dynamic network supporting (FVRT)	P																		
FRT curve settings:																				
<table border="1" style="margin: 10px auto; border-collapse: collapse;"> <caption>Approximate data points from the FRT curve graph</caption> <thead> <tr> <th>Time [s]</th> <th>Voltage U/Un</th> <th>Type</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>1.25</td> <td>Measure point</td> </tr> <tr> <td>2</td> <td>0.85</td> <td>FVRT curve</td> </tr> <tr> <td>2</td> <td>0.5</td> <td>Measure point</td> </tr> <tr> <td>5</td> <td>1.2</td> <td>Measure point</td> </tr> <tr> <td>60</td> <td>0.85</td> <td>Measure point</td> </tr> </tbody> </table>			Time [s]	Voltage U/Un	Type	0	1.25	Measure point	2	0.85	FVRT curve	2	0.5	Measure point	5	1.2	Measure point	60	0.85	Measure point
Time [s]	Voltage U/Un	Type																		
0	1.25	Measure point																		
2	0.85	FVRT curve																		
2	0.5	Measure point																		
5	1.2	Measure point																		
60	0.85	Measure point																		
Fault Type	3-phase fault and 2-phase fault																			
Transformer Type	Dy5																			
NS protection settings	See table 5.5.7 for detail.																			
Any auxilliary power supply in fault ride through?	Yes/No																			
Terminal sequence	For D1: U-L1, V-L2, W-L3 For D2: U-L3, V-L1, W-L2																			

Test Procedure:

Test Equipment:


The test equipment and network simulator must be able to take the max. occurring PGU current, both in generating and motoring area. The energy absorb shall be designed for sudden short circuited current I_p (per IEC 60909). I_p is obvious different by the type of test sample, the correct value shall be:

- for inverter coupled system about $2.2I_n$,
- for direct coupled Asynchronous or Synchronous machines about $7I_n$.

Grid simulator settings for asymmetry grid fault:


D1	Test Equipment	Test Sample
Connection terminal	U	L1
	V	L2
	W	L3 (L for single phase)
D2	Test Equipment	Test Sample
Connection terminal	U	L3
	V	L1 (L for single phase)
	W	L2

Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 52 von 199
 Page 52 of 199

VDE No.	U	V	W	Type	Remark
--	1.00, -150°	1.00, 90°	1.00, -30°	A	Initial status
1.3, 1.4	0.62, -173.3°	0.15, 90°	0.62, -6.9°	D	UVRT
2.3, 2.4, 3.3, 3.4	0.76, -161.1°	0.50, 90°	0.76, -19.1°	D	
4.3, 4.4	0.93, -152.8°	0.85, 89.9°	0.93, -27.4°	D	
5.3, 5.4	1.08, -144.5°	1.25, 89.1°	1.06, -36.3°	D	OVRT
6.3, 6.4	1.06, -145.5°	1.20, 89.3°	1.05, -35.1°	D	
7.3, 7.4	1.04, -146.6°	1.15, 89.4°	1.04, -33.9°	D	

Diagram:

For each test the following diagrams shall be figured since t1-1s (one second before fault entry) till t2+6s (six seconds after fault clear), zoomed if needed:

Empty load tests:

- line to line voltages and line to neutral voltages (signal)
- full period-RMS value of line to neutral voltages with updated rate of 1/ms.

Tests with sample:

- line to line voltage and line to neutral voltage (signal)
- line currents (signal)
- full period-RMS value of line to neutral voltage with updated rate of 1/ms
- full period-RMS value of line currents with updated rate of 1/ms (active and reactive part additionally)
- active power and reactive power in pos. sequence with updated rate of 1/ms
- voltage and current in pos. sequence with updated rate of 1/ms

Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 53 von 199 Page 53 of 199
---	---------------------	------------------------------------

Test	U/Un [p.u.]	Fault type	Fault duration [ms]	P/Pn [p.u.]	Q/Pn [p.u.]	Test No.	
1	0.15....0.25	A	For 0.15pu ≥ 150 For 0.25pu ≥ 500	1.0	0...±0.1	1.1	
				0.2...0.6		1.2	
				1.0		1.3	
		D1		0.2...0.6		1.4	
				D2		1.0	1.3 (D2)
2	0.50....0.60	A	For 0.5pu ≥ 1500 For 0.60pu ≥ 2000	1.0	Max. over-excited	2.1	
				0.2...0.6		2.2	
		D1		1.0		2.3	
				0.2...0.6		2.4	
3	0.50....0.60	A	For 0.5pu ≥ 1500 For 0.60pu ≥ 2000	1.0	Max. under-excited	3.1	
				0.2...0.6		3.2	
		D1		1.0		3.3	
				0.2...0.6		3.4	
4	0.85....0.90	A	≥ 60000	1.0	0...±0.1	4.1	
				0.2...0.6		4.2	
		D1		1.0		4.3	
				0.2...0.6		4.4	
5	1.2....1.25	A	≥ 100	1.0	0...±0.1	5.1	
				0.2...0.6		5.2	
		D1		1.0		5.3	
				0.2...0.6		5.4	
		D2		1.0		5.3 (D2)	
6	1.15...1.20	A	≥ 5000	1.0	0...±0.1	6.1	
				0.2...0.6		6.2	
		D1		1.0		6.3	
				0.2...0.6		6.4	
7	1.10...1.15	A	≥ 60000	1.0	0...±0.1	7.1	
				0.2...0.6		7.2	
		D1		1.0		7.3	




Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003





 Seite 54 von 199
 Page 54 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.1
	1	Date	--	--	dd.mm.yyyy	06.13.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	23:36:53
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.15
	5	Setting dip duration		--		186
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	186
	8	Fault duration in empty load test	Total	--	ms	186
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.15
10	Pos.		p.u.		0.15	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.02
	16		Pos.			-0.02
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.15
	19	Line current	Phase 1	t1+60ms	p.u.	0.00
	20		Phase 2			0.01
	21		Phase 3			0.01
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	0.143
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.02
	32		Pos.			-0.02
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	

Test No. 1.1 idle test






Test No. 1.1 with PGU





Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 58 von 199
 Page 58 of 199





Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 59 von 199
 Page 59 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.2
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	22:58:32
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.15
	5	Setting dip duration		--		186
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	186
	8	Fault duration in empty load test	Total	--	ms	186
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.15
10	Pos.		p.u.		0.15	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.01
	16		Pos.			-0.01
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.15
	19	Line current	Phase 1	t1+60ms	p.u.	0.03
	20		Phase 2			0.03
	21		Phase 3			0.03
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.293
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.01
	32		Pos.			-0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 1.2 idle test



Test No. 1.2 with PGU











Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 64 von 199 Page 64 of 199
---	---------------------	------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	1.3
	1	Date	--	--	dd.mm.yyyy	06.13.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	23:40:54
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--		p.u. 0.15
	5	Setting dip duration		--		186
	6	Point of fault entry	Total	--		ms 0
	7	Point of fault clearance	Total	--		ms 186
	8	Fault duration in empty load test	Total	--		ms 186
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u. 0.15
10	Pos.				p.u. 0.46	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1		p.u. 1.00
	12	Current	Pos.	t1-500ms to t1-100ms		p.u. 0.99
	13	Active power	Total		t1-10s to t1	p.u. 0.99
	14		Pos.			p.u. 0.99
	15	Reactive power	Total		t1-10s to t1	p.u. 0.02
	16		Pos.			p.u. 0.02
17	Cosφ	--		t1-10s to t1	-- 1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms		p.u. 0.15
	19	Line current	Phase 1			p.u. 0.04
	20		Phase 2	t1+60ms		p.u. 0.05
	21		Phase 3			p.u. 0.07
	22	Line current	Phase 1		t1+100ms	p.u. 0.04
	23		Phase 2			p.u. 0.04
	24		Phase 3			p.u. 0.06
	25	Active power	Total		t1+100ms to t2-20ms	p.u. 0.02
26	Pos.				p.u. 0.02	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s		p.u. 1.00
	28	Active power	Total		t2+3s to t2+10s	p.u. 0.94
	29		Pos.			p.u. 0.94
	39	Active power rising time	Pos.	--		s 0.743
	31	Reactive power	Total		t2+3s to t2+10s	p.u. 0.02
	32		Pos.			p.u. 0.02
	33	Reactive power rising time	Pos.	--		s N/A
34	PGU does not disconnect from grid till 60s after fault	--		t2 to t2+60s	Yes / No No	




Test No. 1.3 idle test



Test No. 1.3 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 69 von 199
 Page 69 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.3(D2)
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	22:56:39
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.15
	5	Setting dip duration		--		186
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	186
	8	Fault duration in empty load test	Total	--	ms	186
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.15
10	Pos.		p.u.		0.46	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	0.01
	16		Pos.			0.01
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.15
	19	Line current	Phase 1	t1+60ms	p.u.	0.05
	20		Phase 2			0.06
	21		Phase 3			0.04
	22	Line current	Phase 1	t1+100ms	p.u.	0.04
	23		Phase 2			0.06
	24		Phase 3			0.04
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	0.261
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.01
	32		Pos.			0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	

Test No. 1.3(D2) idle test



Test No. 1.3(D2) with PGU








Prüfbericht-Nr.:
Test report no.:

CN2283DK 003

Seite 73 von 199
Page 73 of 199






Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 74 von 199
 Page 74 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.4
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	22:59:21
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.15
	5	Setting dip duration		--		186
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	186
	8	Fault duration in empty load test	Total	--	ms	186
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.15
10	Pos.		p.u.		0.46	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.01
	16		Pos.			-0.01
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.15
	19	Line current	Phase 1	t1+60ms	p.u.	0.01
	20		Phase 2			0.04
	21		Phase 3			0.03
	22	Line current	Phase 1	t1+100ms	p.u.	0.02
	23		Phase 2			0.03
	24		Phase 3			0.02
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.01
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.299
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.01
	32		Pos.			-0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 1.4 idle test



Test No. 1.4 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 79 von 199
 Page 79 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2.1
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	22:48:39
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.50
	5	Setting dip duration		--		1713
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	1713
	8	Fault duration in empty load test	Total	--	ms	1713
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.50
10	Pos.		p.u.		0.50	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.01
	13	Active power	Total	t1-10s to t1	p.u.	0.91
	14		Pos.			0.91
	15	Reactive power	Total	t1-10s to t1	p.u.	0.44
	16		Pos.			0.44
17	Cos ϕ	--	t1-10s to t1	--	0.902	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.50
	19	Line current	Phase 1	t1+60ms	p.u.	0.02
	20		Phase 2			0.02
	21		Phase 3			0.02
	22	Line current	Phase 1	t1+100ms	p.u.	0.02
	23		Phase 2			0.02
	24		Phase 3			0.02
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.91
	29		Pos.			0.91
	39	Active power rising time	Pos.	--	s	0.781
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.37
	32		Pos.			0.37
	33	Reactive power rising time	Pos.	--	s	9.308
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	





Test No. 2.1 idle test



Test No. 2.1 with PGU











Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 84 von 199 Page 84 of 199
---	---------------------	------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	2.2
	1	Date	--	--	dd.mm.yyyy	06.18.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	11:20:31
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.50
	5	Setting dip duration		--		1713
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	1713
	8	Fault duration in empty load test	Total	--	ms	1713
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.50
10	Pos.		p.u.		0.50	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.22
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	0.10
	16		Pos.			0.10
17	Cosφ	--	t1-10s to t1	--	0.901	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.50
	19	Line current	Phase 1	t1+60ms	p.u.	0.01
	20		Phase 2			0.01
	21		Phase 3			0.01
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.718
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.08
	32		Pos.			0.08
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 2.2 idle test



Test No. 2.2 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003





 Seite 89 von 199
 Page 89 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	2.3
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	22:50:26
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.50
	5	Setting dip duration		--		1709
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	1709
	8	Fault duration in empty load test	Total	--	ms	1709
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.50
10	Pos.		p.u.		0.67	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.01
	13	Active power	Total	t1-10s to t1	p.u.	0.91
	14		Pos.			0.91
	15	Reactive power	Total	t1-10s to t1	p.u.	0.43
	16		Pos.			0.43
17	Cos ϕ	--	t1-10s to t1	--	0.903	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.50
	19	Line current	Phase 1	t1+60ms	p.u.	0.03
	20		Phase 2			0.02
	21		Phase 3			0.03
	22	Line current	Phase 1	t1+100ms	p.u.	0.03
	23		Phase 2			0.02
	24		Phase 3			0.03
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.91
	29		Pos.			0.91
	39	Active power rising time	Pos.	--	s	0.434
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.36
	32		Pos.			0.36
	33	Reactive power rising time	Pos.	--	s	9.496
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	





Test No. 2.3 idle test



Test No. 2.3 with PGU











Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 94 von 199 Page 94 of 199
---	---------------------	------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	2.4
	1	Date	--	--	dd.mm.yyyy	06.18.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	11:21:22
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.50
	5	Setting dip duration		--		1709
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	1709
	8	Fault duration in empty load test	Total	--	ms	1709
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.50
10	Pos.		p.u.		0.67	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.22
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	0.09
	16		Pos.			0.09
17	Cosφ	--	t1-10s to t1	--	0.904	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.50
	19	Line current	Phase 1	t1+60ms	p.u.	0.01
	20		Phase 2			0.01
	21		Phase 3			0.01
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.944
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.08
	32		Pos.			0.08
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 2.4 idle test



Test No. 2.4 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 99 von 199
 Page 99 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3.1
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	22:52:31
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.50
	5	Setting dip duration		--		1713
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	1713
	8	Fault duration in empty load test	Total	--	ms	1713
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.50
10	Pos.		p.u.		0.50	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	0.90
	14		Pos.			0.90
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.44
	16		Pos.			-0.44
17	Cos ϕ	--	t1-10s to t1	--	0.900	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.50
	19	Line current	Phase 1	t1+60ms	p.u.	0.02
	20		Phase 2			0.02
	21		Phase 3			0.02
	22	Line current	Phase 1	t1+100ms	p.u.	0.02
	23		Phase 2			0.02
	24		Phase 3			0.02
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.90
	29		Pos.			0.90
	39	Active power rising time	Pos.	--	s	0.754
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.37
	32		Pos.			-0.37
	33	Reactive power rising time	Pos.	--	s	9.159
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No





Test No. 3.1 idle test



Test No. 3.1 with PGU











Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 104 von 199 Page 104 of 199
---	---------------------	--------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	3.2
	1	Date	--	--	dd.mm.yyyy	06.18.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	11:22:14
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--		p.u. 0.50
	5	Setting dip duration		--		1713
	6	Point of fault entry	Total	--		ms 0
	7	Point of fault clearance	Total	--		ms 1713
	8	Fault duration in empty load test	Total	--		ms 1713
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1		p.u. 0.50
10	Pos.		p.u. 0.50			
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.22
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.10
	16		Pos.			-0.10
17	Cosφ	--	t1-10s to t1	--	0.900	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.50
	19	Line current	Phase 1	t1+60ms	p.u.	0.01
	20		Phase 2			0.01
	21		Phase 3			0.01
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.818
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.08
	32		Pos.			-0.08
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 3.2 idle test



Test No. 3.2 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 109 von 199
 Page 109 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3.3
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	22:54:50
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.50
	5	Setting dip duration		--		1709
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	1709
	8	Fault duration in empty load test	Total	--	ms	1709
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.50
10	Pos.		p.u.		0.67	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	0.90
	14		Pos.			0.90
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.44
	16		Pos.			-0.44
17	Cos ϕ	--	t1-10s to t1	--	0.898	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.50
	19	Line current	Phase 1	t1+60ms	p.u.	0.03
	20		Phase 2			0.02
	21		Phase 3			0.03
	22	Line current	Phase 1	t1+100ms	p.u.	0.03
	23		Phase 2			0.02
	24		Phase 3			0.03
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.90
	29		Pos.			0.90
	39	Active power rising time	Pos.	--	s	0.421
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.37
	32		Pos.			-0.37
	33	Reactive power rising time	Pos.	--	s	9.312
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	





Test No. 3.3 idle test



Test No. 3.3 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 114 von 199
 Page 114 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	3.4
	1	Date	--	--	dd.mm.yyyy	06.18.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	11:23:54
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.50
	5	Setting dip duration		--		1709
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	1709
	8	Fault duration in empty load test	Total	--	ms	1709
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.50
10	Pos.		p.u.		0.67	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.22
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.10
	16		Pos.			-0.10
17	Cos ϕ	--	t1-10s to t1	--	0.901	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.50
	19	Line current	Phase 1	t1+60ms	p.u.	0.01
	20		Phase 2			0.01
	21		Phase 3			0.01
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.00
26	Pos.		0.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.987
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.08
	32		Pos.			-0.08
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 3.4 idle test



Test No. 3.4 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 119 von 199
 Page 119 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	4.1
	1	Date	--	--	dd.mm.yyyy	0
	2	Time (start of test)	--	--	hh:mm:ss.f	0:00:00
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	0.85
	5	Setting dip duration		--		60512
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	60512
	8	Fault duration in empty load test	Total	--	ms	60512
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.85
10	Pos.		p.u.		0.85	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.03
	16		Pos.			-0.03
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.85
	19	Line current	Phase 1	t1+60ms	p.u.	1.21
	20		Phase 2			1.22
	21		Phase 3			1.22
	22	Line current	Phase 1	t1+100ms	p.u.	1.17
	23		Phase 2			1.17
	24		Phase 3			1.18
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.83
26	Pos.		0.83			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	0.492
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.03
	32		Pos.			-0.03
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 4.1 idle test



Test No. 4.1 with PGU











Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 124 von 199 Page 124 of 199
---	---------------------	--------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	4.2
	1	Date	--	--	dd.mm.yyyy	0
	2	Time (start of test)	--	--	hh:mm:ss.f	0:00:00
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--		p.u. 0.85
	5	Setting dip duration		--		60512
	6	Point of fault entry	Total	--		ms 0
	7	Point of fault clearance	Total	--		ms 60512
	8	Fault duration in empty load test	Total	--		ms 60512
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1		p.u. 0.85
10	Pos.		p.u. 0.85			
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	0.20
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			-0.01
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.01
	16		Pos.			0.997
17	Cosφ	--	t1-10s to t1	--	0.85	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.25
	19	Line current	Phase 1	t1+60ms	p.u.	0.24
	20		Phase 2			0.24
	21		Phase 3			0.24
	22	Line current	Phase 1	t1+100ms	p.u.	0.23
	23		Phase 2			0.23
	24		Phase 3			0.20
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.20
26	Pos.		1.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	0.20
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			N/A
	39	Active power rising time	Pos.	--	s	-0.01
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.01
	32		Pos.			N/A
	33	Reactive power rising time	Pos.	--	s	No
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	0.20	




Test No. 4.2 idle test



Test No. 4.2 with PGU














Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 129 von 199 Page 129 of 199
---	---------------------	--------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	4.3
	1	Date	--	--	dd.mm.yyyy	0
	2	Time (start of test)	--	--	hh:mm:ss.f	0:00:00
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--		p.u. 0.85
	5	Setting dip duration		--		60508
	6	Point of fault entry	Total	--		ms 0
	7	Point of fault clearance	Total	--		ms 60508
	8	Fault duration in empty load test	Total	--		ms 60508
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u. 0.85
10	Pos.				p.u. 0.90	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.03
	16		Pos.			-0.03
17	Cosφ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.85
	19	Line current	Phase 1	t1+60ms	p.u.	1.12
	20		Phase 2			1.13
	21		Phase 3			1.10
	22	Line current	Phase 1	t1+100ms	p.u.	1.11
	23		Phase 2			1.13
	24		Phase 3			1.09
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.90
26	Pos.			0.90		
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	0.315
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.03
	32		Pos.			-0.03
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	

Test No. 4.3 idle test






Test No. 4.3 with PGU





Prüfbericht-Nr.:
 Test report no.:




CN2283DK 003

 Seite 133 von 199
 Page 133 of 199



Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 134 von 199 Page 134 of 199
---	---------------------	--------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	4.4
	1	Date	--	--	dd.mm.yyyy	0
	2	Time (start of test)	--	--	hh:mm:ss.f	0:00:00
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--		p.u. 0.85
	5	Setting dip duration		--		60508
	6	Point of fault entry	Total	--		ms 0
	7	Point of fault clearance	Total	--		ms 60508
	8	Fault duration in empty load test	Total	--		ms 60508
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1		p.u. 0.85
10	Pos.		p.u. 0.90			
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.01
	16		Pos.			-0.01
17	Cosφ	--	t1-10s to t1	--	0.997	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.85
	19	Line current	Phase 1	t1+60ms	p.u.	0.22
	20		Phase 2			0.23
	21		Phase 3			0.22
	22	Line current	Phase 1	t1+100ms	p.u.	0.21
	23		Phase 2			0.22
	24		Phase 3			0.22
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.20
26	Pos.		0.20			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	N/A
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.01
	32		Pos.			-0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 4.4 idle test



Test No. 4.4 with PGU







Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003





 Seite 139 von 199
 Page 139 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.1
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:02:43
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.25
	5	Setting dip duration		--		153
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	153
	8	Fault duration in empty load test	Total	--	ms	153
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.25
10	Pos.		p.u.		1.25	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.99
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	0.02
	16		Pos.			0.02
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.25
	19	Line current	Phase 1	t1+60ms	p.u.	0.01
	20		Phase 2			0.00
	21		Phase 3			0.01
	22	Line current	Phase 1	t1+100ms	p.u.	0.02
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.01
26	Pos.		-0.01			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.99
	29		Pos.			0.99
	39	Active power rising time	Pos.	--	s	0.516
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.02
	32		Pos.			0.02
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	

Test No. 5.1 idle test






Test No. 5.1 with PGU





Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 143 von 199
 Page 143 of 199





Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 144 von 199
 Page 144 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.2
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	23:00:55
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.25
	5	Setting dip duration		--		153
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	153
	8	Fault duration in empty load test	Total	--	ms	153
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.25
10	Pos.		p.u.		1.25	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.01
	16		Pos.			-0.01
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.24
	19	Line current	Phase 1	t1+60ms	p.u.	0.03
	20		Phase 2			0.03
	21		Phase 3			0.03
	22	Line current	Phase 1	t1+100ms	p.u.	0.02
	23		Phase 2			0.02
	24		Phase 3			0.03
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.02
26	Pos.		0.02			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.343
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.01
	32		Pos.			-0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 5.2 idle test



Test No. 5.2 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003





 Seite 149 von 199
 Page 149 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.3
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:06:41
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.25
	5	Setting dip duration		--		150
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	150
	8	Fault duration in empty load test	Total	--	ms	150
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.25
10	Pos.		p.u.		1.13	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.99
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	0.02
	16		Pos.			0.02
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.25
	19	Line current	Phase 1	t1+60ms	p.u.	0.00
	20		Phase 2			0.00
	21		Phase 3			0.00
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.00
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.01
26	Pos.		-0.01			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	0.51
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.02
	32		Pos.			0.02
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 5.3 idle test



Test No. 5.3 with PGU










Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 154 von 199 Page 154 of 199
---	---------------------	--------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	5.3(D2)
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	22:57:30
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--		p.u. 1.25
	5	Setting dip duration		--		150
	6	Point of fault entry	Total	--		ms 0
	7	Point of fault clearance	Total	--		ms 150
	8	Fault duration in empty load test	Total	--		ms 150
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1		p.u. 1.25
10	Pos.		p.u. 1.13			
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	0.01
	16		Pos.			0.01
17	Cosφ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.25
	19	Line current	Phase 1	t1+60ms	p.u.	0.06
	20		Phase 2			0.06
	21		Phase 3			0.07
	22	Line current	Phase 1	t1+100ms	p.u.	0.06
	23		Phase 2			0.06
	24		Phase 3			0.07
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.03
26	Pos.		0.03			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.01
	29		Pos.			1.01
	39	Active power rising time	Pos.	--	s	0.162
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.01
	32		Pos.			0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 5.3(D2) idle test



Test No. 5.3(D2) with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 159 von 199
 Page 159 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.4
	1	Date	--	--	dd.mm.yyyy	06.16.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	23:01:41
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.25
	5	Setting dip duration		--		150
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	150
	8	Fault duration in empty load test	Total	--	ms	150
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.25
10	Pos.		p.u.		1.13	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.01
	16		Pos.			-0.01
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.24
	19	Line current	Phase 1	t1+60ms	p.u.	0.04
	20		Phase 2			0.03
	21		Phase 3			0.03
	22	Line current	Phase 1	t1+100ms	p.u.	0.03
	23		Phase 2			0.02
	24		Phase 3			0.02
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.02
26	Pos.		0.02			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.348
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.01
	32		Pos.			-0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 5.4 idle test



Test No. 5.4 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 164 von 199
 Page 164 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6.1
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:08:47
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.20
	5	Setting dip duration		--		5199
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	5199
	8	Fault duration in empty load test	Total	--	ms	5199
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.20
10	Pos.		p.u.		1.20	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	0.02
	16		Pos.			0.02
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.20
	19	Line current	Phase 1	t1+60ms	p.u.	0.01
	20		Phase 2			0.01
	21		Phase 3			0.02
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.01
26	Pos.		-0.01			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	0.291
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.02
	32		Pos.			0.02
	33	Reactive power rising time	Pos.	--	s	N/A
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No




Test No. 6.1 idle test



Test No. 6.1 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 169 von 199
 Page 169 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	6.2
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:09:40
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.20
	5	Setting dip duration		--		5199
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	5199
	8	Fault duration in empty load test	Total	--	ms	5199
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.20
10	Pos.		p.u.		1.20	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	0.01
	16		Pos.			0.01
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.20
	19	Line current	Phase 1	t1+60ms	p.u.	0.01
	20		Phase 2			0.00
	21		Phase 3			0.02
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.01
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.01
26	Pos.		-0.01			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.24
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.01
	32		Pos.			0.01
	33	Reactive power rising time	Pos.	--	s	N/A
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No




Test No. 6.2 idle test



Test No. 6.2 with PGU











Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 174 von 199 Page 174 of 199
---	---------------------	--------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	6.3
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:10:29
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--		p.u. 1.20
	5	Setting dip duration		--		5198
	6	Point of fault entry	Total	--		ms 0
	7	Point of fault clearance	Total	--		ms 5198
	8	Fault duration in empty load test	Total	--		ms 5198
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1		p.u. 1.20
10	Pos.		p.u. 1.10			
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	0.02
	16		Pos.			0.02
17	Cosφ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.20
	19	Line current	Phase 1	t1+60ms	p.u.	0.00
	20		Phase 2			0.00
	21		Phase 3			0.00
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.00
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.01
26	Pos.		-0.01			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	0.288
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.02
	32		Pos.			0.02
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 6.3 idle test



Test No. 6.3 with PGU











Prüfbericht-Nr.: Test report no.:	CN2283DK 003	Seite 179 von 199 Page 179 of 199
---	---------------------	--------------------------------------





Condition						Measurement
	No.	Parameter	Phase ref.	Time ref.	unit	
General Info.	0	Test number	--	--	--	6.4
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:11:29
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.20
	5	Setting dip duration		--		5198
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	5198
	8	Fault duration in empty load test	Total	--	ms	5198
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.20
10	Pos.		p.u.		1.10	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	0.01
	16		Pos.			0.01
17	Cosφ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.20
	19	Line current	Phase 1	t1+60ms	p.u.	0.00
	20		Phase 2			0.01
	21		Phase 3			0.01
	22	Line current	Phase 1	t1+100ms	p.u.	0.01
	23		Phase 2			0.00
	24		Phase 3			0.01
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.01
26	Pos.		-0.01			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	0.24
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.01
	32		Pos.			0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 6.4 idle test



Test No. 6.4 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 184 von 199
 Page 184 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7.1
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:14:22
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.15
	5	Setting dip duration		--		60498
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	60498
	8	Fault duration in empty load test	Total	--	ms	60498
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.15
10	Pos.		p.u.		1.15	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.99
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	0.02
	16		Pos.			0.02
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.15
	19	Line current	Phase 1	t1+60ms	p.u.	0.81
	20		Phase 2			0.81
	21		Phase 3			0.83
	22	Line current	Phase 1	t1+100ms	p.u.	0.84
	23		Phase 2			0.83
	24		Phase 3			0.84
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	1.00
26	Pos.		1.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	N/A
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.02
	32		Pos.			0.02
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	

Test No. 7.1 idle test






Test No. 7.1 with PGU





Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003

 Seite 188 von 199
 Page 188 of 199





Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 189 von 199
 Page 189 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7.2
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:16:19
	3	Fault type (phase)	--	--		3-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.15
	5	Setting dip duration		--		60498
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	60498
	8	Fault duration in empty load test	Total	--	ms	60498
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.15
10	Pos.		p.u.		1.15	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.20
	13	Active power	Total	t1-10s to t1	p.u.	0.20
	14		Pos.			0.20
	15	Reactive power	Total	t1-10s to t1	p.u.	0.01
	16		Pos.			0.01
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.15
	19	Line current	Phase 1	t1+60ms	p.u.	0.16
	20		Phase 2			0.17
	21		Phase 3			0.17
	22	Line current	Phase 1	t1+100ms	p.u.	0.15
	23		Phase 2			0.16
	24		Phase 3			0.16
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.20
26	Pos.		0.20			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.20
	29		Pos.			0.20
	39	Active power rising time	Pos.	--	s	N/A
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.01
	32		Pos.			0.01
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 7.2 idle test



Test No. 7.2 with PGU










Prüfbericht-Nr.:
 Test report no.:

CN2283DK 003


 Seite 194 von 199
 Page 194 of 199





Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	7.3
	1	Date	--	--	dd.mm.yyyy	06.14.2022
	2	Time (start of test)	--	--	hh:mm:ss.f	0:18:05
	3	Fault type (phase)	--	--		2-phase fault
	4	Setting voltage depth	Line to line	--	p.u.	1.15
	5	Setting dip duration		--		60498
	6	Point of fault entry	Total	--	ms	0
	7	Point of fault clearance	Total	--	ms	60498
	8	Fault duration in empty load test	Total	--	ms	60498
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.15
10	Pos.		p.u.		1.08	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.00
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.00
	13	Active power	Total	t1-10s to t1	p.u.	1.00
	14		Pos.			1.00
	15	Reactive power	Total	t1-10s to t1	p.u.	0.02
	16		Pos.			0.02
17	Cos ϕ	--	t1-10s to t1	--	1.000	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.15
	19	Line current	Phase 1	t1+60ms	p.u.	0.85
	20		Phase 2			0.88
	21		Phase 3			0.87
	22	Line current	Phase 1	t1+100ms	p.u.	0.92
	23		Phase 2			0.96
	24		Phase 3			0.94
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	1.00
26	Pos.		1.00			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.00
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.00
	29		Pos.			1.00
	39	Active power rising time	Pos.	--	s	N/A
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.02
	32		Pos.			0.02
	33	Reactive power rising time	Pos.	--	s	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	No	




Test No. 7.3 idle test



Test No. 7.3 with PGU







Prüfbericht-Nr.: <i>Test report no.:</i>	CN2283DK 003	Seite 199 von 199 <i>Page 199 of 199</i>
--	---------------------	---

Revision History:

Date YYYY-MM-DD	Contents of modification (latest on top)	Prepared by	Approved by
2020-07-08	Originated and released into QM system	Tobias Yang	Weichun Li

PHOTO DOCUMENTATION

CN2283DK 003


for

Grid-connected PV Inverter

APEX-P3-xx(xx=3000, 4000, 5000, 6000, 7000, 8000,
9000, 10K, 12K, 15K),

APEX-P3-xx-G(xx=3000, 4000, 5000, 6000, 7000,
8000, 9000, 10K, 12K, 15K)

Apex Solar Energy Technology GmbH




This documentation consists of 3 pages (excluding this cover page)

Report Number: CN2283DK 003

Model: APEX-P3-xx(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K),
APEX-P3-xx-G(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K)




Overall view



Side view 1

Report Number: CN2283DK 003

Model: APEX-P3-xx(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K),
APEX-P3-xx-G(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K)




Side view 2




Bottom view

Report Number: CN2283DK 003

Model: APEX-P3-xx(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K),
APEX-P3-xx-G(xx=3000, 4000, 5000, 6000, 7000, 8000, 9000, 10K, 12K, 15K)



Top view



Back view